


GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2019 / 2155

Dated: 27/11/2019

FIRE SAFETY CERTIFICATE

Certified that **M.C Primary Girls School**, located at **Shakti Nagar, Delhi-110007** comprised of **Ground & 01 Upper floor** owned/occupied by **M.C Primary Girls School** was issued FSC by this department vide letter no. **No.F6/DFS/MS/School/2016/WZ/1337** dated **01.09.2016**. The premises was re-inspected by the officer concerned of this department on **21.10.2019** in presence of **Mrs. Gurmeet kaur (Principal)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from/5.7.11.19..... for a period of **three years**, subject to compliance of the conditions mentioned below:


(Dharampal Bhardwaj)
Dy.Chief Fire Officer
Ph.-011-25104544

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 54.
2. The Principal, M.C Primary Girls School, Shakti Nagar, Delhi-110007

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form “K”** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 “The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form ‘J’** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry”.

INSPECTION REPORT

1. Name & address of the building : M.C Primary Girls School, Shakti Nagar, Delhi-110007.
 2. Type of Occupancy : Educational
 3. Type of Case : Renewal (Ground +01 upper floor)
 4. Details of previous NOC : F6/DFS/MS/School/2016/WZ/1337 dated: 01.09.2016
 5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
 6. Date of inspection : 21.10.2019
 7. Name of the Inspecting Officers : ADO (RN)
 8. Name and designation of officers
 from the building side : Mrs. Gurmeet Kaur (Principal)
 9. Year of Construction : 1993
 10. Applicant's letter No. : Nil Diary No.-20359 Dated: 13.09.2019

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/MR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m	1.50m & 1.52m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	2m NA	3.21m	MR NA
	f. Door Size	1.00 m	1.22m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA

