GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2019 / 2143

Dated: 14/11/2019

FIRE SAFETY CERTIFICATE

> (Dharampal Bhardwaj) Dy.Chief Fire Officer Ph.-011-25104544

> > EM

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 54.

2. The Principal, M.C Primary School, A-Block, DDA Flats, Jahangir Puri, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

1 All the means of escape/entry/exit shall be kept free from any obstruction.

2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.

3. All the staff members must know the correct method of operation of firefighting system.

4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms.

5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.

6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

9. Name & address of the building

: M.C Primary School, Punjabi Medium, DDA Flat, Jahangirpuri,, Delhi-110033.

10. Type of Occupancy

:Educational

11. Type of Case

: Renewal (Ground +02 upper floor)

12. Details of previous NOC

: F6/DFS/MS/2015/School/WZ/1618 dated:08.09,2015 Ground floor Only

13. Fire Safety directives letter No

: Director of Education Circular dated 01.03.2011

14. Date of inspection

: 22.10.2019

: ADO (RN)

15. Name of the Inspecting Officers

16. Name and designation of officers

from the building side

: Sh. Dinesh Singh (Principal)

9. Year of Construction

: 1991

10. Applicant's letter No.

: Nil Diary No.-20980 Dated: 24.09.2019

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR		
V	Access to building					
	Road width	Accessible	Accessible	MR		
	Gate width	Accessible	Accessible	MR		
	Width of internal road	NA	NA	NA		
	Number, Width, Type & Arrangement of Exits	ber, Width, Type & Arrangement of Exits				
	a. Number of staircases					
	Upper Floors	NA	NA	NA		
	Basements	NA	NA	NA		
	b. Width of staircases	NA NA				
		NA	NA	INA.		
	Upper Floors Programments	NA	NA	NA		
	Basements					
	c. Protection of exits • Fire check door	NA	NA	NA		
	Pressurization	NA	NA	NA		
	d. No. of continuous staircases to terrace	NA	NA	NA		
	e. Width of Corridor	NA	NA	NA		
	f. Door Size	1m	1m each	MR		
3	Compartmentation.					
	Fire check door	NA	NA	NA		