

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110 001**

No.F6/DFS/MS/FW/2019/ 2157

Dated 15/11/19

**FIRE SAFETY CERTIFICATE**

Certified that the M/s New Shri Ram Fireworks running the trade of sale of possession of fireworks quantity 100 KG manufactured fireworks and 500 KG Chinese/Sparklers on ground floor at shop 469/1-A/3, Shalimar Park, Bhola Nath Nagar, Delhi-110032, comprised of ground plus one upper floor owned/occupied by M/s New Shri Ram Fireworks was granted FSC by this department vide letter No. F6/DFS/MS/FW/2016/NDZ/1022 dated 13/06/16 (only for ground floor). The shop was re-inspected by the officer concerned of this department on 23/10/19 in the presence of Sh. Ramlal and found that the shop No. 469/1-A/3 have deemed complied with the fire prevention and fire safety requirements in accordance with the Delhi Police Act and found that the shop is fit for occupancy class Fireworks storage with effect from .....15/11/19.....renewed for a period of three years, subject to conditions printed below.

Issued on.....15/11/19.....at New Delhi by

(Atul Garg)  
Director

To,

1. The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, P.S. Defence colony, New Delhi.
2. Sh. Ramlal

M/s New Shri Ram Fireworks at Shop 469/1-A/3, Shalimar Park, Bhola Nath Nagar,  
Delhi-110032

**Conditions for the validity of Fire Safety Certificate**

1. M/s New Shri Ram Fireworks is directed to abide by the direction of Hon'ble Supreme Court issued vide Writ Petition(Civil) No. 728 of 2015 titled as Arjun Gopal and Other versus Union of India. and are allowed/directed to sell only permissible category of fire crackers certified by PESO.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. All comments/directions of the Licensing Department shall always be permitted and followed.
9. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate six months prior to its expiry"

1. Name & address of the building : M/s **New Shri Ram** Fireworks

shop 469/1-A/3, Shalimar Park, Bhola Nath Nagar,  
Delhi-110032

2. Type of Occupancy : Storage Fireworks

3. Type of Case : Renewal

4. Details of Previous FSC : F6/DFS/MS/FW/2016/NDZ/1022 dated 13/06/16

5. Fire Safety direction letter No : -----

6. Date of Inspection : 23/10/2019

7. Name of the Inspecting Officers : ADO Nagender Singh

8. Name of the Person from the  
Building side : **Sh. Ramlal**

9. Year of Construction : 2015

10. Applicant letter no. : 222-232/Addl.CP/Lic.(Expl.) dated 07/10/2019

Sr. No.	Point of Inspection	Requirement	Provided at Site	Remarks MR/NMR
1	Type of construction and floor area & floor level			
	a. Minimum floor area	9m <sup>2</sup> (Min.)	3.20 m <sup>2</sup> x3.20 m <sup>2</sup>	MR
	b. Construction	Pucca	Provided	MR
	c. Premises Location	Not under the staircase/Mean of escape	Provided	MR
	d. Business permissible only at ground floor level	Required	Provided	MR
	e. Business from pavement of road prohibited	Prohibited	Yes	MR
2	Entrance & Exits to the licensed premises			
	The licensed premises shall have independent entrance and exit	Required	Provided (Yes)	MR
3	Type and distance of the surrounding risk			
	The premises shall be situated at a distance of 15 m from any such premises used for similar explosives/ inflammable or hazardous materials.	Required 15 mtr	Provided	MR



4	Nature of business run in the licensed premises			
	The premises in which fireworks are kept shall be used only for possession and sale for fireworks and no other purposes.	Required	Provided (yes)	MR
5.	Type of electrical wiring and electrical fittings			
	Preferably concealed or through conduit	Required	Provided	MR
	All electrical fitting should be flame/spark proof	Required	Provided with Casing & Capping.	MR
6	Extension of Shop for Business.	Prohibited	Yes	MR
7	Approach Road			
	The road width on the side of which premises is located should be 12m.	12 M	15 M	MR
8	Fire Protection Arrangement.			
	Extinguishers (Type & No's.)	2 nos. water type & 1 no. of ABC or Co <sub>2</sub> type	Provided	MR
	Sand and Water Buckets	2 nos. each	Provided	MR
	Water Drum(s)	1 nos.	Provided	MR
9	Any other point that is contrary to the safety of people.			

The fire protection systems provided in shop were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire Safety measures as required under the rules, it is recommended to renew Fire Safety Certificate.

Signature of the Inspecting Officer  
 Name -Nagender Singh  
 Designation -ADO(Shd)

~~DO NOT~~ *31/12*

*DR. LALMAN*

*Director*

*5/11*

*FTB*  
*ADMSD*