

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/SZ/2019/ 2173

Dated: 15/11/19

FIRE SAFETY CERTIFICATE

Certified that **gds. P.G.D.A.V. Senior Secondary School located at West Patel Nagar, New Delhi- 110008** having two blocks namely Old Block & New Block. Old Block is comprised of ground floor only and New Block is comprised of ground plus one upper floor, was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2015/SZ/1631 dated 09/09/2015. The school building was re-inspected by the officer concerned of this department on 19/10/2019 in presence of Sh. Neeraj Kumar Singh (principal) and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years subject to compliance of the conditions printed overleaf.

Issued on 15/11/19 at New Delhi by.

(Rajesh Panwar)
Dy. Chief Fire Officer
Ph.01126179168

Copy to: -

1. The Principal, P.G. D.A.V. Senior Secondary School, West Patel Nagar, New Delhi- 05.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi- 110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

INSPECTION REPORT

1. Name & address of the building : P.G.D.A.V. Sr. Sec. School, West Patel Nagar, New Delhi-110008.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2015/SZ/1631 dated 09.09.2015
5. Fire Safety directives letter No : DoE Cir. No. F.16/Estate/CC/Fire Safety/2011//3298-3398 dt. 01.03.2011
6. Date of inspection : 19.10.2019
7. Name of the Inspecting Officers : Rajbir Kharb, ADO (Shankar Road)
8. Name and designation of officers from the building side : Sh. Neeraj Kumar Singh, Principal
9. Year of Construction : Before 2002, 2008
10. Applicant's letter No. : PGDAV/WPN/19/3889 dated 17.09.2019

The School building is having two blocks namely Old Block & New Block. Old Block is comprised of ground floor only and New Block is comprised of ground plus one upper floor.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per DoE circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	6 mts Old Case N/A	Provided 3.4 mts N/A	MR MR, old case N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	<ul style="list-style-type: none"> Upper Floors Basements 	01 N/A	02 N/A	MR N/A
	b. Width of staircases	-----	-----	-----
	<ul style="list-style-type: none"> Upper Floors Basements 	1.5 mts or less & 0.75 mt N/A	1.75, 1.0 mts N/A	MR N/A
	c. Protection of exits	-----	-----	-----
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.0 mts	Provided (1.12 mts)	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	N/A Natural Vent.	N/A MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	10 nos. ABC type ISI	Provided Provided	MR MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	Provided	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level	---	----	-----
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	----	-----	-----
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A

N-18

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:			
		N/A	N/A	N/A

The fire protection systems provided in the building were tested / checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No F.6/DFS/MS/School/2015/SZ/1631 dated 09-09-2015, renewal under rule 33 of Delhi Fire Service Rules 2010, is recommended.

DFA is put up for approval and signature please.

DO(SW)

11/11/2018

(Rajbir Kharb)
Asstt. Div. Officer, (S.Rd)

DCFO(SZ)

13/11

936
11/11/19

13/11

ADD(SRO)

