

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

NO. F6/DFS/MS/EH/2019/SZ/ 2178

Dated: 18/11/19

**FIRE SAFETY CERTIFICATE**

Certified that the M/s. Password Restaurant at Plot No.3, 1<sup>st</sup> floor, Manish Twin Plaza, Ashirwad Chowk, Sector-11, Dwarka, New Delhi-110075, running at 1<sup>st</sup> floor of the building comprised of ground plus three upper floors was issued Fire safety Certificate in the name & style of Spice Shot Restaurant by this department vide letter No. F6/DFS/MS/EH/2017/SZ/852 dated 22.12.2017. The premises was re-inspected by officer concerned of this department on 4.11.2019 in presence of Sh. Ram Sagar (Manager) and found that the restaurant building have deemed complied with fire prevention and safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the building is fit for occupancy class D "Assembly building "Restaurant" with effect from.....18.11.19..... for a period of **three** years subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on .....18/11/19..... at New Delhi by

(Vipin Kental)  
Chief Fire Officer  
Jc

Copy to:-

1. The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> floor, Police Station, Defence Colony, New Delhi.
2. The Deputy Health Officer, South Delhi Municipal Corporation, Public Health Department, Najafgarh Zone, New Delhi.
3. Ms. Pushpa Rai, the Password Restaurant, Plot No.3, Manish Twin Plaza, 1<sup>st</sup> floor, Ashirwad Chowk, Sector-11, Dwarka, New Delhi-110075.

### CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

	Name & address of the building	1st floor, Sector 11, Noida 110075		
2	Type of Occupancy	Assembly "D" Restaurant		
3	Type of case	Renewal	(Name Change)	
4	Details of previous NOC	No. F-6/DFS/MS/EH/2017/SZ/852 dated 22.12.2017		
5	Fire safety directives letter No	Old Case/Circular dated 11.11.2005		
6	Date of inspection	4.11.2019		
7	Name of the inspecting Officers :	ADO S.P Bhardwaj (Dwarka)		
8	Name and designation of officers from the building side	Sh. Ram Sagar (Manager)		
9	Year of construction	Before 2008	Restaurant Runinig at 1st Floor	
10	Applicant's letter No.	Nil dated 1.10. 2019	Building Comprised of Ground + 3 upper Floors	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per letter dated 22.12.2017	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			
	1) Road width	9 mtrs	Provided	MR
	2) Gate width	4.5 Mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	One	One	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.25 Mtrs.	Provided	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Requied	One	MR
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	1.20 & 1 Mtr.	Provided	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	basement		N/A	N/A
			Exhaust Fan	MR


	total numbers	6 Nos.	ABC	MR
	Types	CO2 & WCO	Provided	MR
	ISI marking	ISI Marked		
<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	1 No.	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	MR
	hooter's location	N/A	N/A	MR
<b>8</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9</b>	<b>Public Address System.</b>	N/A	N/A	N/A
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	Required	Provided in Restaurant Area	MR
	sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	100 MM	Provided	MR
	Number of Hydrants per floor	One	Provided	MR
	hose Box	Required	Provided	MR
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping arrangements</b>			
	<b>1. Ground level/</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
		450, 180 LPM	Provided	MR
	a. Discharge of pump			
	b. head of the pump	35 Mtrs.	35 Mtrs	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5000 Ltrs.	5000 Ltrs.	MR
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16</b>	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A

2/17

17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Fire extinguisher provided near electric panel MR			

Fire protection systems provided in the building were checked and found functional at the time of inspection. The Shortcomings vide letter no. F6/DFS/MS/EH/2019/South/4955 Dated 16.08.2019 found rectified. Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules, renewal of FSC issued vide letter no. F6/DFS/MS//EH/2017/SZ/852 dated 22.12.2017 is recommended.

Accordingly DFA is put up for approval and signature please.

  
 S.P Bhardwaj  
 ADO (DWARKA)

done

8/11/19

DGF(S2)

481  
8/11/19

camp  
11/12

14/11/19

FT will be ready  
14/11/19  
by  
FAT

ADU DWARKA

FT is put up for signature please

