

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/BNQT/SZ/2019/ 2135

Dated: 14/11/19

**FIRE SAFETY CERTIFICATE**

Certified that M/s. Petal Banquet (M/s. Shiv Shakti Hotels Pvt. Ltd.) located at A-21/18, Naraina Industrial Area, Phase- II, New Delhi- 110028, running on ground floor of a building comprised of basement, ground plus two & half upper floors was granted Fire Safety Certificate vide this department letter No. F.6/DFS/MS/BNQT/2015/SZ/1801 dated 08.10.2015 for ground floor only. The banquet hall was re-inspected by the officer concerned of this department on 30.10.2019 in presence of Sh. Rohit Kalra (manager) and found that the management of M/s. Petal Banquet (Shiv Shakti Hotels Pvt. Ltd.) have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group D 'Assembly Building', (for Ground Floor only) with effect from 14/11/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued 14/11/19 at New Delhi by.

(Atul Garg)  
Director

Delhi Fire Service

Copy to:-

1. The Manager, M/s. Petal Banquet (M/s. Shiv Shakti Hotels Pvt. Ltd.), A-21/18, Naraina Industrial Area, Phase- II, New Delhi- 110028.
2. The Additional C.P. (Lic.), Police Station Defence Colony, 1<sup>st</sup> floor, New Delhi.
3. Municipal Health officer , NDMC, Civic centre, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing department shall always be permitted and followed.
7. If the owner/occupier open the wall connected with A-21/17, the FSC will be automatically null & void.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
9. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

**INSPECTION REPORT**

1. Name & address of the building : M/s. Petal Banquets, 21/18, Naraina Industrial Area, Phase- II, New Delhi
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/BNQ/2015/SZ/1801 dated 08.10.2015
5. Fire Safety directives letter No : N/A
6. Date of inspection : 30.10.2019
7. Name of the Inspecting Officers : Rajbir Kharb, ADO (Shankar Road)
8. Name and designation of officers from the building side : Sh. Rohit Kalra, manager
9. Year of Construction : 2005-06
10. Applicant's letter No. : nil dated 18.10.2019

The said banquet hall is running on ground floor of a building comprised of basement, ground plus two & half upper floors.

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per NBC/BBL	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> </ul>	06 mts	Provided	MR
	<ul style="list-style-type: none"> <li>• Gate width</li> </ul>	Old case	2.70, 2.10 & 1.06 mts	MR being old case
	<ul style="list-style-type: none"> <li>• Width of internal road</li> </ul>	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	<ul style="list-style-type: none"> <li>• Upper Floors</li> </ul>	N/A	N/A	B. hall at GF only
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	02 nos.	02 nos.	MR
	b. Width of staircases	-	-	-
	<ul style="list-style-type: none"> <li>• Upper Floors</li> </ul>	N/A	N/A	B. hall at GF only
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	Old case	1.20, 1.16 mts	B. hall at GF only
	c. Protection of exits	-	-	-
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	---	01	B. hall at GF only
	g. Width of Corridor	N/A	N/A	B. hall at GF only
	h. Door Size	Old case	1.10 mts	MR being old case
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	N/A	Sealed	----
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	Exhaust fan provided	MR
	<ul style="list-style-type: none"> <li>• Upper floors/ Ground floor</li> </ul>	12 a/c per hour	Exhaust fan provided	MR
5	<b>Fire Extinguishers</b>			

	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	10 ABC & CO <sub>2</sub> type ISI marked	Provided ABC & CO <sub>2</sub> type Provided	MR M MR
6.	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 30 m 5 mm	Provided Provided Provided	MR MR MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A N/A N/A Required N/A	Smoke Provided at GF N/A D.G set 160 & 62.5 KVA N/A	---- ---- N/A MR N/A
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor / Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required Required N/A	Provided Provided N/A	MR MR N/A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 mm 01 No. 01 No.	Provided Provided Provided	MR MR MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A N/A	N/A N/A	N/A N/A
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	--- N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 900 LPM 30 mts N/A N/A	--- N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A Provided Provided N/A N/A	--- N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A MR MR N/A N/A
14	<b>Captive Water Storage for fire fighting</b>			

	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	N/A	Provided	----
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Overhead Tank capacity</li> </ul>	15000 lts	15000 lts	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts. Provided but not commissioned</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Pressurization of Lift lobby</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Communication In lift Car</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Fireman's Grounding Switch</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Lift Signage</li> </ul>	Required	Provided	MR
17	<b>Standby power supply</b>	Required	Provided D.G set	MR
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Location</li> </ul>	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Flow Switch Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• PA System Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Batter backup</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	02 ABC type fire extinguishers found Provided near elect. panel	MR



The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/BNQ/2015/SZ/1801 dated 08.10.2015, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

DFA is put up for approval & signature please.

Note: All the shortcomings pointed out by this department vide letters dated 26.01.2019 & 17.01.2019 have been complied with by the management.

The management of above mentioned banquet hall had interconnect the ground floor of the A-21/18 with ground floor and set back areas of other property i.e. A-21/17 but now the management has reduced the extended areas and now the banquet hall is running only on the ground floor of the A-21/18, Naraina Industrial Area, Phase- II, New Delhi.

*DO (SW)*

*7/11/2019*

*6/11/2019*

DCFO (SZ)

Rajbir Kharb  
ADO (Shankar Road)