

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/BNQT/SZ/2019/ 2135

Dated: 14/11/19

FIRE SAFETY CERTIFICATE

Certified that M/s. Petal Banquet (M/s. Shiv Shakti Hotels Pvt. Ltd.) located at A-21/18, Naraina Industrial Area, Phase- II, New Delhi- 110028, running on ground floor of a building comprised of basement, ground plus two & half upper floors was granted Fire Safety Certificate vide this department letter No. F.6/DFS/MS/BNQT/2015/SZ/1801 dated 08.10.2015 for ground floor only. The banquet hall was re-inspected by the officer concerned of this department on 30.10.2019 in presence of Sh. Rohit Kalra (manager) and found that the management of M/s. Petal Banquet (Shiv Shakti Hotels Pvt. Ltd.) have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group D 'Assembly Building', (for Ground Floor only) with effect from 14/11/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued 14/11/19 at New Delhi by.

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Manager, M/s. Petal Banquet (M/s. Shiv Shakti Hotels Pvt. Ltd.), A-21/18, Naraina Industrial Area, Phase- II, New Delhi- 110028.
2. The Additional C.P. (Lic.), Police Station Defence Colony, 1st floor, New Delhi.
3. Municipal Health officer , NDMC, Civic centre, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing department shall always be permitted and followed.
7. If the owner/occupier open the wall connected with A-21/17, the FSC will be automatically null & void.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

