

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI

No. F6/DFS/MS/EH/2019/ 2190

Dated: 14/11/2019

FIRE SAFETY CERTIFICATE

Certified that the **M/S Raj Kamal Banquet**, located at **3rd Floor Commercial Complex Plot No -2 Community Centre Block -B, Shop in Park Mall, Shalimar Bagh, Delhi - 110088** in a building comprised of Lower Basement + Upper Basement + Ground + 3 Upper Floors owned/occupied by **M/S Raj Kamal Banquet** was issued FSC vide Letter No. F6/DFS/MS/Banquet/2016/WZ/586 Dated 13/04/2016 and the premises was re inspected by the officers concerned of this department on 16/10/2019 in the presence of Sh. Ravi Kaushik and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 14/11/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on14/11/19... at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. M/S Raj Kamal Banquet, Commercial Complex Plot No -2 Community Centre Block -B Shop in Park Mall 3 rd Floor, Shalimar Bagh, Delhi - 110088.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used a for any purpose.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expired.

INSPECTION REPORT

1. Name & address of the building: **M/S Raj Kamal Banquet**, Located at **Commercial Complex Plot No -2 Community Centre Block -B Shop in Park Mall 3 rd Floor, Shalimar Bagh, Delhi – 110088.**
2. Type of Occupancy : **Banquet (Assembly) At 3rd Floor Shop in Park Mall**
3. Type of Case : **Renewal**
4. Details of previous NOC ; Letter No. **F6/DFS/MS/Banquet/2016/WZ/586** Dated **13/04/2016(Issued to mall - F6/DFS/MS/WZ/2019/1907 dated 03/10/2019)**
5. Fire Safety directives Letter No. : **Nil**
6. Date of inspection : **16/10/2019**
7. Name of the Inspecting Officer : **Udai Vir Singh ADO (WP)**
8. Name and designation of Officer
from the building side : **Sh. Ravi Kaushik**
9. Year of Construction : **2006**
10. Applicant's letter No. : **Nil Dated 21/08/2019**

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	212 m	Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	7	7 Provided	MR
	• Basements	NA	Provided	NA
	b. Width of staircases			
	• Upper floors	7x150 cm	4x160cm, 1x155cm & 2x151cm	MR
	• Basements	NA	Provided	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2x2m & 1x1m	Provided 2x2m & 1x140cm	MR(For Banquet)

3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	Provided	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System		Common with Mall	
	• Basements	NA(for Banquet)	Provided	NA
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	08(For Banquet)	Provided	MR
	• Types	ABC, CO2 & WCO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels	Common With Mall		
	• Total numbers on each floor	5	Provided	MR
	• Length of hose reel hose	36 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	Provided	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants Common With Mall			
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	5	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants(Common With Mall)			
	• Total number of hydrants	NA	Provided	NA
	• Hose Box	NA	Provided	NA

13.	Pumping Arrangements(Common With Mall)			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump 	2850 lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of main pump 	70 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps 	2	Provided	MR
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	180 lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Jockey pump head 	70 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	2850 lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	75 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto Staring/Manual stopping 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Pump House Access 	Required	Provided	MR
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of the pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Power supply 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto starting of pump 	NA	NA	NA
14.	Captive water Storage for fire fighting(Common With Mall)			
	<ul style="list-style-type: none"> Under ground tank capacity 	2,00,000 litres	Provided	MR
	<ul style="list-style-type: none"> ➤ Draw of connection 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	30, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts(Common With Mall)			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Communication in lift Car 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Fireman's Grounding Switch 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Lift Signage 	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Location 	NA	NA	NA
19.	Fire control room (Common With Mall)			
	<ul style="list-style-type: none"> ➤ Detector system panel 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Flow Switch Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ PA System Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Battery backup 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Building Floor Plans 	Required	Provided	MR

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	Provided	NA
-----	--	----	----------	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/Banquet/2016/WZ/586 Dated 13/04/2016 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note:- Addition alteration if any shall be checked by building sanctioning authority.

Signature of the Inspecting Officer

Name Vir Singh

Designation ADG/WP

Signature of the Inspecting Officer

Name

Designation

D/O 16/11/19

D/O WZ 11/11/19

cto on cl
Director 11/11/19 FP

Ang/WP Sir FP letter is put up for

sign please. 10 18/11/19

Director 13/11/19
m