

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/WZ/2019/ 2170

Dated: 15/11/2019

FIRE SAFETY CERTIFICATE

Certified that the **Ravi Kishore Enterprises Pvt. Ltd.** Located at **B-12, Lawrence Road Industrial Area, New Delhi-110035** in a building comprised of Lower Basement + Upper Basement + Ground Floor + Mez Floor + First Floor & Second Floor, owned/ occupied by **Ravi Kishore Enterprises Pvt. Ltd.** was issued FSC vide Letter No. F6/DFS/MS/2016/1213 Dated 25/11/16. The premises was re inspected by the officers concerned of this department on 21/10/2019 in the presence of Sh. Kishore Arora (Partner) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 15/11/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on15/11/19..... at New Delhi by.

(Atul Garg)
Director

Delhi Fire Service

Copy to:- The Ravi Kishore Enterprises Pvt. Ltd. Located at B-12, Lawrence Road Industrial Area, New Delhi-110035.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : **Ravi Kishore Enterprises Pvt. Ltd.**
Located at **B-12, Lawrence Road Industrial Area, New Delhi-110035.**
2. Type of Occupancy: Banquet, (L. Basement + U Basement + Ground Floor + Maz Floor + First Floor & Second Floor Only.
3. Type of Case :Renewal
4. Details of previous NOC ; F6/DFS/MS/2016/1213 Dated 25/11/16
5. Fire Safety directives Letter No. :F6/DFS/MS/BP/2014/43 Dated 24/01/14
6. Date of inspection : 21-10-2019
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Kishore Arora (Pa
9. Year of Construction : 2015-16
10. Applicant's letter No. : Nil Dated – Nil

Basement=Parking
Banquet=At Ground, 1st & 2nd Floors
Mezzanine Floors= Bridal Room and Office

| S No | Minimum standards on fire prevention and fire safety U/R 33 | NBC Requirements | Provided at site | Remarks MR/NMR |
|------|---|-------------------------------------|---|----------------|
| 1. | Access of building | | | |
| | • Road width | 12 m | Provided | MR |
| | • Gate width | 6m | Provided (On open Road) | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 2 | 2 Provided | MR |
| | • Basements | 2 | 2 Provided | MR |
| | b. Width of staircases | | | |
| | • Upper floors | 2x2 m M.F=1x2m&1x1m | FF & SF=1x200 cm & 1x205 cm Mez F=1x2m & 1m | MR |
| | • Basements | 2x2 m, & Ramp 2x450cm | 1x200 cm & 1x205 cm & Ramp 2x450cm | MR |
| | c. Protection of exits | | | |
| | • Fire check door | Required | Provided | MR |
| | • Pressurization | Required | Provided | MR |
| | d. No of continuous staircase to terrace | Required | Provided | MR |
| | e. Width Of Corridor | NA | NA | NA |
| | f. Door Size | 2x2m & 1x1m for office at mez floor | GF=2x220cm, 1x210cm&1x214cm Mez=1x105cm(office) FF=1x220cm&1x210cm 2 nd F=1x220cm&1x210cm | MR |

| | | | | |
|----|--|-----------------|-------------------|----|
| 3. | Compartmentation | | | |
| | • Fire check door | Required | Provided | MR |
| | • Sealing of electrical shafts | Required | Provided | MR |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | Required | Provided | MR |
| | • Fire Dampers | Required | Provided | MR |
| 4. | Smoke managements System | | | |
| | • Basements | 30a/c per hrs | Provided | MR |
| | • Upper floors | 12 a/c per hour | Provided | MR |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 35 | 35 Provided | MR |
| | • Types | ABC, CO2 & WCO2 | Provided | MR |
| | • IS marking | ISI marked | Provided | MR |
| 6. | First – Aid Hose Reels | | | |
| | • Total numbers on each floor | 2 | 2 Provided | MR |
| | • Length of hose reel hose | 36 m | Provided | MR |
| | • Nozzle diameter | 5 mm | Provided | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | Smoke & Heat | Provided | MR |
| | • Location of Main Panel | Required | Provided | MR |
| | • Location of Repeater Panel | Required | Provided | MR |
| | • Alternate source of power | Required | Provided | MR |
| | • Hooters' Location | Required | Provided | MR |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | Required | Provided | MR |
| 10 | Automatic Sprinkler System | | | |
| | • Basements | Required | Provided | MR |
| | • Upper Floor | Required | Provided | MR |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | • Size of riser/down- comer | 100 mm | Provided | MR |
| | • Number of hydrants per floor | 2 | 2 Provided | MR |
| | • Hose Box | Required | Provided | MR |
| 12 | Yard Hydrants | | | |
| | • Total number of hydrants | 6 | 6 Provided | MR |
| | • Hose Box | 6 | 6 Provided | MR |
| 13 | Pumping Arrangements | | | |
| | • Ground Level | | | |
| | • Discharge of main pump | 2280 lpm | 2280 lpm Provided | MR |
| | ➤ Head of main pump | 70 m | 70m Provided | MR |
| | ➤ Number of main pumps | 1 | Provided | MR |
| | ➤ Jockey pump out put | 180 lpm | 180 lpm Provided | MR |
| | ➤ Jockey pump head | 70 m | 70m Provided | MR |
| | ➤ Standby Pump out put | 2280 lpm | 2280 lpm Provided | MR |
| | ➤ Standby Pump Head | 70 m | 70 m Provided | MR |
| | ➤ Auto Staring/Manual stopping | Required | Provided | MR |
| | ➤ Pump House Access | Required | Provided | MR |
| | • Terrace level | | | |
| | ➤ Discharge of pump | 450lpm | 45 lpm Provided | MR |
| | ➤ Head of the pump | 40m | 40 m Provided | MR |
| | ➤ Power supply | Required | Provided | MR |
| | ➤ Auto starting of pump | Required | Provided | MR |

| | | | | |
|----|--|-----------------|----------|----|
| 14 | Captive water Storage for fire fighting | | | |
| | • Under ground tank capacity | 1,00,000 litres | Provided | MR |
| | ➤ Draw of connection | Required | Provided | MR |
| | ➤ Fire service inlet | Required | Provided | MR |
| | ➤ Access to tank | Required | Provided | MR |
| | • Overhead Tank cpty | 10, 000 litres | Provided | MR |
| 15 | Exit Signage | Required | Provided | MR |
| 16 | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | Required | Provided | MR |
| | ➤ Pressurization of lift lobby | Required | Provided | MR |
| | ➤ Communication in lift Car | Required | Provided | MR |
| | ➤ Fireman's Grounding Switch | Required | Provided | MR |
| | ➤ Lift Signage | Required | Provided | MR |
| 17 | Standby power supply | Required | Provided | MR |
| 18 | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19 | Fire control room | | | |
| | ➤ Detector system panel | Required | Provided | MR |
| | ➤ Flow Switch Panel | Required | Provided | MR |
| | ➤ PA System Panel | Required | Provided | MR |
| | ➤ Battery backup | Required | Provided | MR |
| | ➤ Building Floor Plans | Required | Provided | MR |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any; | Required | Provided | MR |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no. F6/DFS/MS/2016/1213 Dated 25/11/16 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
Name

Designation

Signature of the Inspecting Officer
Name

Designation

23/10/19
Virender Singh
ASO (WP)
15/11/19
11/11/19