

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**


No. F6/DFS/MS/School/SZ/2019/ 2174

Dated: 15/11/19

**FIRE SAFETY CERTIFICATE**

Certified that the building of **S.D. Public School**, located at 20, Beadon Pura, Karol Bagh, New Delhi- 05, comprised of ground plus three upper floors was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2016/SZ/1610 dated 31.10.2016. The said school building was re-inspected by the officer concerned of this department on 29.10.2019 in the presence of Smt. Anjali Bhatnagar (Principal) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Services Rules, 2010 and that the building/premises is fit for occupancy class B "Educational Building", with effect from 15/11/19 for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on 15/11/19 at New Delhi by.

  
(Rajesh Panwar)  
Dy. Chief Fire Officer  
Ph.01126179168

Copy to: -

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal, S.D. Public School, 20, Beadon Pura, Karol Bagh, New Delhi- 05.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

