

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6 DFS/MS/School/2019/SZ/2166

Dated: 15/11/19

FIRE SAFETY CERTIFICATE

Certified that the Sai Public School located at B-398,399,Tigri,New Delhi 110062 comprised of ground plus two upper floors was granted fire safety certificate by this department vide letter No. F6/DFS/MS/2006/3146 Dated 20/10/2006. The premises was re-inspection by officer concerned by this department on 04/11/2019 in the presence of Mr. Harender Sharma (Admin) of the school and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular No. 262-362 dated 17/01/05 issued by Education Directorate, Govt. of NCT of Delhi, Old secretariat and that the school building is fit for occupancy class "Educational Building" Group-B, as above with effect from the date of issue of this certificate for a period of Three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/11/19 at New Delhi by


(Rajesh Panwar)
Dy. Chief Fire Officer
Tel. 011-26189168

Copy to: -

1. The Principal, Sai Public School located at B-398,399,Tigri, New Delhi 110062.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

2/6

INSPECTION REPORT

1	Name & Address of the Building	Sai Public School, B-398, 399, Tigri, New Delhi 110062		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground plus two upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/2006/3146 Dated 20/10/2006		
6	Fire Safety Directives Letter No	DOE Circular No-262-362 Dated 17/01/2005		
7	Date of Inspection	04/11/2019		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Harender Sharma (Admin)		
10	Year of construction	2005		
11	Applicant letter No.	Nil dated 05/09/2019		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	As Per Old NOC-2006	Provided at Site	Remarks MR/NMR
1	Access to Building.	Accessible	6m	MR
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase	02 No's	03 Nos	MR
	<ul style="list-style-type: none"> Upper floors. Basement floor. 	-NA-	-NA-	-NA-
	b) Width of Staircase			MR
	<ul style="list-style-type: none"> Upper floors Basement floor 	Required	0.75 & 0.62, 0.89m (G to f floor)	Old Case
		-NA-	-NA-	-NA-
	c) Protection of exits			-NA-
	<ul style="list-style-type: none"> Fire check door Pressurization 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	01 No	Provided 01No's	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	-NA-	-NA-	-NA-
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	30 ACPH	-NA-	-NA-
		12 ACPH	-NA-	-NA-
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	Required	06Nos	MR
		ABC / CO2	ABC & Co2	MR
		ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	01 no	Provided	MR
		30m	Provided	MR
		5m	Provided	MR

20/7

7.	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	-NA-	-NA-	-NA-
	• Number of Hydrant per floor	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting / Manual Stopping.	-NA-	-NA-	-NA-
	➤ Pump house access.	-NA-	-NA-	-NA-
	• Terrace Level			
	➤ Discharge of pump.	225 LPM	Provided	MR
	➤ Head of pump.	30m	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	• Underground tank capacity.	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	2,500liter	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

2/8

19.	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.			-NA-


Note: There are three staircases in the school building instead of two as mentioned in previous report, it seems that there has been omission in the previous inspection report. Also no addition / alteration has been done in the school building.

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection

The shortcoming issued by the department vide letter No. F6/DFS/MS/School/2018/SZ/1822 dated 04/05/18 have been rectified. The declaration form submitted by the school management at C-11 for no construction change in building.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE circular, FSC issued vide letter No. F6/DFS/MS/2006/3146 Dated 20/10/2006, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.


Signature of the Inspecting Officer
Name: Mehmoode
Design: ADO (SJ)

~~DO (SD)~~

Line
07/11


DCAFO(S2)


9/11

DO / SM

SEO
11/11

ADO (SJ)

Sw. A. G. T. Delhi put up for signature please

12/11/18
ADDRESS

