

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/School/2019/SZ/2165

Dated: 15/11/19

FIRE SAFETY CERTIFICATE

Certified that the SDMC Primary School(Girls/Boys) located at DDA-II, Kalkaji, New Delhi-110019 comprised of ground plus one upper floor only was issued FSC by this department vide letter No. F6/DFS/MS/SZ/School/2016/918 Dated 02/06/2016. The premises was re-inspection by officer concerned by this department on 06/11/2019 in the presence of Mrs. Rubina (Principal) of the school and found that fire prevention and fire safety requirements have deemed complied in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Education Directorate, Govt. of NCT of Delhi, and that the premises fit for occupancy class Education Building, Group-B as above with effect from the date of issue of this certificate for period of three years subject to compliance of conditions mentioned below.

Issued on 15/11/19 at New Delhi by

(Rajesh Panwar)
Dy. Chief Fire Officer
Tel. 011-26189168

Copy to: -

1. The Principal, SDMC Primary School (Girls/Boys), DDA-II, Kalkaji, New Delhi-110019.
2. Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002.

Conditions for the validity of Fire Safety Certificate


1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	SDMC Primary School (Girls/Boys), DDA-II, Kalkaji, New Delhi-110019		
2	Type of Occupancy	Educational "Group-B" (School)		
3	Building Comprised of	Ground plus one floor Only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/SZ/School/2016/918 Dated 02/06/2016		
6	Fire Safety Directives Letter No	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 1.03.2011		
7	Date of Inspection	06/11/2019		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mrs. Rubina (Principal)		
10	Year of construction	2008		
11	Applicant letter No.	Nil dated 11/09/2019		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	As Per Old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Required 4mtr N/A	Approachable 4mtr N/A	MR MR N/A
2	Number, width, type & arrangement of exits			
	a) Number of Staircase			
	➤ Upper floors	01no	02nos	MR
	➤ Basement floor	N/A	N/A	N/A
	b) Width of Staircase			
	➤ Upper floors	1.50m	1.73m each	MR
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	One	Provided	MR
	e) Width of corridor	1.5m	Provided	MR
	f) Door size	1mtr	1mtr	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	N/A N/A N/A N/A NA	N/A N/A N/A N/A NA	N/A N/A N/A N/A NA
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	30 ACPH 12 ACPH	NA Open Corridor	NA MR
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	08 No's ABC / CO2 ISI marked	08No's ABC & CO2 Provided	MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A


7	Automatic fire detection & alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12.	Yard Hydrants.			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby pump head.	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump.	N/A	N/A	N/A
	➤ Head of pump.	N/A	N/A	N/A
	➤ Power supply.	N/A	N/A	N/A
	➤ Auto starting of pump.	N/A	N/A	N/A
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provisions of Lifts.			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

N/110


19. Fire Control Room.							
	• Detector System Panel.	N/A	N/A	N/A			
	• Flow Switch Panel.	N/A	N/A	N/A			
	• PA system Panel.	N/A	N/A	N/A			
	• Battery backup	N/A	N/A	N/A			
	• Building floor plan	N/A	N/A	N/A			
20.	Special Fire Protection System for the Protection of special Risk, if any.			N/A			
The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection							
Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE circular, FSC issued vide letter No. F6/DFS/MS/SZ/School/2016/918 Dated 02/06/2016 renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended							
Accordingly, DFA is put up for approval and signature please.							
 Signature of the Inspecting Officer Name: Mehmood Designation: ADO (SJ)							


DO (SD)


11/11


DCFO (S2)



11/11


DO (SM)



13/11


ADO (SJ)


Sir. A R-T letter put up for signature please


DCFO (S2)


10/11


14/11/19
ADO (SJ)
