

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/BNQT/SZ/2019/ 2218

Dated: 26/11/19

FIRE SAFETY CERTIFICATE

Certified that M/s. Continental Device India Pvt. Ltd. located at C-120, Naraina Industrial Area, Phase- I, New Delhi- 110028, comprised of basement, ground, mezzanine plus two upper floors was granted Fire Safety Certificate vide this department letter No. F.6/DFS/MS/94/253 dated 22.02.1994. The building was re-inspected by the officer concerned of this department on 30.10.2019 in presence of Sh. Kumar Srinivasan, Vice President and found that the management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group 'G' (Industrial), with effect from 26/11/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued 26/11/19 at New Delhi by.

VC 25/11
(Vipen Kental)
Chief Fire Officer
Ph. No. 011-23412225

Copy to:-

1. The Authorized Signatory, M/s. Continental Device India Pvt. Ltd., C-120, Naraina Industrial Area, Phase- I, New Delhi- 110028.
2. The Dy. Commissioner (F), MCD Factory Licensing Department, Nigam Bhawan, Kashmere Gate, Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing department shall always be permitted and followed.
7. If the owner/occupier open the wall connected with A-21/17, the FSC will be automatically null & void.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

