

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2019/SZ/ 22/11

Dated: 25/11/19

FIRE SAFETY CERTIFICATE

Certified that the Delhi Public School (International) Primary & Nursery School located at Sector-10, R.K. Puram, New Delhi-110022 comprised of basement (storage only), ground plus two upper floors was granted fire safety certificate by this department vide letter No. F6/MS/DFS/2004/1197 Dated 03/06/2004. The premises was re-inspection by officer concerned by this department on 16/11/2019 in the presence of Mrs. Vanita (Principal) of the school and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of Delhi Fire Service Rules 2010 and that the school building is fit for occupancy class "Educational Building" Group-B, as above with effect from the date of issue of this certificate for a period of Three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/11/19 at New Delhi by

(Rajesh Panwar)
Dy. Chief Fire Officer
Tel. 011-26189168

Copy to: -

1. The Principal, Delhi Public School (International) Primary & Nursery School, Sector-10, R.K. Puram, New Delhi-110022
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.


2/5

INSPECTION REPORT

| | | | | |
|--------|--|--|---------------------|-------------------|
| 1 | Name & Address of the Building | Delhi Public School (International) Primary & Nursery School Sec 10, R.K. Puram, New Delhi-110022 | | |
| 2 | Type of Occupancy | Educational, Group-B (School) | | |
| 3 | Building Comprised of | Basement, Ground Plus Two upper floors (Basement Garage) | | |
| 4 | Type of Case | Renewal | | |
| 5 | Details of Previous NOC | F6/MS/DFS/2004/1197 Dated 03/06/2004 | | |
| 6 | Fire Safety Directives Letter No | F.6/DFS/MS/BP/2003/2192 dated 19/09/2003 | | |
| 7 | Date of Inspection | 16/11/2019 | | |
| 8 | Name of the Inspecting Officers | Mehmood, ADO (SJ) | | |
| 9 | Name & Designation of Officers from the building side | Mr. B.B. Sharma (Admin) | | |
| 10 | Year of construction | 2003 | | |
| 11 | Applicant letter No. | DPSI/Admin/462 dated 08/10/2019 | | |
| S. No. | Minimum standards on Fire Prevention and Fire Safety U/R33 | As Per Directives (old case) | Provided at Site | Remarks MR/NMR |
| 1 | Access to Building. | | | |
| | • Road width | 9m | 9m | MR |
| | • Gate width | 5m | Provided | MR |
| | • Width of internal road | -NA- | -NA- | -NA- |
| 2 | Number, width, type & arrangement of exits. | | | |
| | a) Number of Staircase | | | |
| | ➤ Upper floors. | Two | Three | MR |
| | ➤ Basement floor. | Two | Three | MR |
| | b) Width of Staircase | | | |
| | ➤ Upper floors | Required | 1.37, 1.30 m & 1m | MR |
| | ➤ Basement floor | Required | 1.38m, 1.37m & 1m | MR |
| | c) Protection of exits | | | |
| | ➤ Fire check door | Required | Provided | MR |
| | ➤ Pressurization | -NA- | -NA- | -NA- |
| | d) No. of continuous staircase to terrace | One | One | MR |
| | e) Width of corridor | 1.5m | Provided | MR |
| | f) Door size | 1m | Provided | MR |
| 3 | Compartmentation. | | | |
| | • Fire check door. | Required | Provided | MR |
| | • Sealing of electrical shafts. | -NA- | -NA- | -NA- |
| | • Fire rating of shaft door. | -NA- | -NA- | -NA- |
| | • Water curtain | -NA- | -NA- | -NA- |
| | • Fire dampers. | -NA- | -NA- | -NA- |
| 4. | Smoke Management system. | | | |
| | • Basement | 30 A/c Per Hour | Exhaust Fan | MR |
| | • Upper floors | 12 A/c Per Hour | Natural Ventilation | MR |
| 5. | Fire Extinguishers. | | | |
| | • Total numbers | 52Nos | 52 Nos | MR |
| | • Types | ABC / CO2 | ABC & Co2 | MR |
| | • ISI Marking | ISI marked | Provided | MR |
| 6. | First Aid Hose Reels. | | | |
| | • Total numbers on each floor. | Upper Floor-Three Basement -Two | Provided | MR |
| | • Length of hose-reel hose. | 30m | Provided | MR |
| | • Nozzle Diameter | 5mm | Provided | MR |

| | | | | |
|-----|--|-------------------------------------|-------------------------------------|------|
| 7 | Automatic fire detection & alarming system. | | | |
| | • Type of detectors | Smoke | Provided | MR |
| | • Location of Main Panel | Ground Floor | Provided | MR |
| | • Location of Repeater Panel | -NA- | -NA- | -NA- |
| | • Alternate source of power | -NA- | -NA- | -NA- |
| | • Hooter's location | -NA- | -NA- | -NA- |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | Required | Provided | MR |
| 10. | Automatic Sprinkler System | | | |
| | • Basement | Required | Provided | MR |
| | • Upper floors | -NA- | -NA- | -NA- |
| | • Sprinkler above false ceiling | -NA- | -NA- | -NA- |
| 11. | Internal Hydrants. | | | |
| | • Size of Riser/Down-comer | 100mm | Provided | -NA- |
| | • Number of Hydrant per floor | Upper Floors-3no Basement -02nos | Upper Floors-3no Basement -02nos | -NA- |
| | • Hose box. | Upper Floors-3no Basement -02nos | Upper Floors-3no Basement -02nos | -NA- |
| 12. | Yard Hydrants. | | | |
| | • Total number of hydrants. | NA | Provided | NA |
| | • Hose box. | NA | Provided | NA |
| 13. | Pumping arrangements. | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main pump. | 1620LPM | 2280LPM | MR |
| | ➤ Head of main pump. | 70m | 70m | MR |
| | ➤ Number of main pumps. | One | Provided | MR |
| | ➤ Jockey Pump output. | 180LPM | Provided | MR |
| | ➤ Jockey Pump head. | 70m | 70m | MR |
| | ➤ Standby Pump output. | 1620LPM | 2280LPM | MR |
| | ➤ Standby Pump head. | 70m | 70m | MR |
| | ➤ Auto Starting / Manual Stopping. | Required | Provided | MR |
| | ➤ Pump house access. | Required | Provided | MR |
| | • Terrace Level | | | |
| | ➤ Discharge of pump. | 900 LPM | 900LPM | MR |
| | ➤ Head of pump. | 40m | 40m | MR |
| | ➤ Power supply. | Required | Provided | MR |
| | ➤ Auto starting of pump. | Required | Provided | MR |
| 14. | Captive water storage for firefighting. | | | |
| | • Underground tank capacity. | 50,000liter | Provided | MR |
| | ➤ Draw-off connection. | -NA- | -NA- | -NA- |
| | ➤ Fire Service Inlet. | -NA- | -NA- | -NA- |
| | ➤ Access to tank. | -NA- | -NA- | -NA- |
| | • Overhead tank capacity. | 10,000 ltr | 20,000 ltr | MR |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | • Pressurization of lift shaft. | -NA- | -NA- | -NA- |
| | • Pressurization of lift lobby. | -NA- | -NA- | -NA- |
| | • Communication in lift car. | -NA- | -NA- | -NA- |
| | • Fireman's switch. | Required | Provided | MR |
| | • Lift signage. | Required | Provided | MR |
| 17. | Standby Power Supply | Required | Provided (DG Set) | MR |

N/7

| | | | | |
|--|---|------|------|------|
| 18. | Refuge Area | | | |
| | • Total area | -NA- | -NA- | -NA- |
| | • Location | -NA- | -NA- | -NA- |
| 19. | Fire Control Room. | | | |
| | • Detector system panel. | -NA- | -NA- | -NA- |
| | • Flow switch panel. | -NA- | -NA- | -NA- |
| | • PA system panel. | -NA- | -NA- | -NA- |
| | • Battery backup. | -NA- | -NA- | -NA- |
| | • Building floor plan. | -NA- | -NA- | -NA- |
| 20. | Special Fire Protection System for the Protection of special Risk, if any. | | | |
| <p>The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection</p> <p>Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules 35, FSC issued vide letter No. F6/MS/DFS/2004/1197 Dated 03/06/2004 Dated 03/06/2004, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly DFA is put up for approval and signature please.</p> <div style="text-align: right;">  Signature of the Inspecting Officer Name: Mehmoed Designation: ADO(SJ) </div> | | | | |

DO (SD)

21/11/19

DCFO(SJ)

21/11

DO (SJ)

22/11

ADO(SJ)

Sir. A. S. T. Return put up in. Org as per order

25/11/19
ADO(SJ)

DCFO(SJ)

25/11

