

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001


No.F.6/DFS/MS/School/2019/NDZ/ 2184

Dated: 21/11/19

FIRE SAFETY CERTIFICATE

Certified that the East End Public School running at ground & first floor building comprised of basement (vacant) ground & first floor at B-1/12, New Ashok Nagar, Delhi-110096, owned/occupied by East End Public School have complied with the fire prevention and fire safety requirements in accordance with the Circular No. 262-362 dated 17/01/2005 issued by the Director of Education and verified by the officer concerned of this department on 10/10/19 & 11/11/19 in the presence of Mr. Rahul (coordinator) of the school and found that the school building ground & first floor is fit for occupancy class B 'Educational Building' for with effect from 21/11/19 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 21/11/19 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

To,

1. The Principal,
East End Public School,
B-1/12, New Ashok Nagar, Delhi-110096.

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

1. Name & address of the building : East End Public School, B-1/12, New Ashok Nagar, Delhi-110096.
2. Building is comprised of : Basement, G+1 (school at gr. & first floor only)
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous FSC : Nil
6. Fire Safety direction letter No : Circular No. 262-362 dated 17/01/2005
7. Date of Inspection : 10/10/19 & 11/11/19
8. Name of the Inspecting Officers : R.K. Yadav (ADO)
9. Name of the designation of Officer from the building side : Mr. Rahul (Coordinator)
10. Year of Construction : Nil dated 16/09/19
11. Applicant's letter No


S.No	Minimum Standards on fire prevention & fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			MR
	Road width	6 m	20 m	N.A
	Gate width	N.A	N.A	N.A
	Width of internal road	N.A	N.A	N.A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			MR
	Upper Floor	2 no.	2 no.	N.A
	Basement	N.A	N.A	
	B. Width of Staircases			MR
	Upper Floor	1.5 m	1.22 m each	N.A
	Basement	N.A	N.A	N.A
	c. Protection of exits			N.A
	Fire check door	N.A	N.A	N.A
	Pressurization	N.A	N.A	N.A
	d. No. of continuous staircases to terrace	01 no.	01 no.	MR
	e. Width of Corridor	1.5 m	1.5 m	MR
	f. Door Size	1 m	1.0 m	MR
3	Compartmentation.			
	Fire check door	N.A	N.A	N.A
	Sealing of electrical shafts	N.A	N.A	N.A
	Fire rating of shaft door	N.A	N.A	N.A
	Water curtain	N.A	N.A	N.A
	Fire Dampers	N.A	N.A	N.A
4	Smoke Management System.			
	Basement	N.A	N.A	N.A
	Upper floor	N.A	N.A	N.A
5.	Fire Extinguisher			
	Total numbers	06 nos.	06 nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
		ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 nos.	01 nos.	MR
	Length of hose reel hose	30 mm	30 mm	MR
	Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A	N.A	N.A
	Location of main panel	N.A	N.A	N.A
	Location of repeater panel	N.A	N.A	N.A
	Alternate source of power	N.A	N.A	N.A
	Hooters	N.A	N.A.	N.A.
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A	Provided	MR
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	upper floor	N.A	N.A	N.A
	sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	size of riser/down-comer	N.A	N.A	N.A
	Number of hydrants per floor	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
12	Yard Hydrants.			
	Total number of hydrants	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	Ground Level	N.A	N.A	N.A
	Discharge of main Pump	N.A	900 LPM	MR
	Head of Main Pump	N.A	40 M	MR
	Number of main pumps	N.A	N.A	N.A
	Jockey pump out put	N.A	N.A	N.A
	Jockey pump head	N.A	N.A	N.A
	Standby pump out put	N.A	N.A	N.A
	Standby pump Head	N.A	N.A	N.A
	Auto Starting /Manual stopping	N.A	N.A	N.A
	Pump House Access	N.A	N.A	N.A
	Terrace Level			
	Discharge of pump	450 LPM	450 LPM	MR
	Head of the Pump	40 M	40 M	MR
	Power supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A	5000 liters	MR
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	5000 liters	5000 liters	MR
15	Exit Signage.	Required	Provided	MR


N/S

16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	N.A	N.A	N.A
	Firemen's grounding switch	N.A	N.A	N.A
	Lift Signage	N.A	N.A	N.A
17	Standby power supply	N.A	N.A	N.A
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	N.A	N.A	N.A
	Flow switch panel	N.A	N.A	N.A
	PA system panel	N.A	N.A	N.A
	Batter backup	N.A	N.A	N.A
	Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A


The fire protection systems provided in the building were tested/checked at the time of inspection. Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the Circular No. 262-362 dated 17/01/20051 Director of Education, it is recommended to grant Fire Safety Certificate.

Signature of the Inspecting officer 
 Name- R.K.Yadav
 Designation- ADO(LN)

DO(East)


 15/11/2025
Dr. UBI NDM

Speak on 2(A).
 Remd on 31/Y


 31/X