

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001


No.F.6/DFS/MS/School/2019/NDZ/ 2184

Dated: 21/11/19

FIRE SAFETY CERTIFICATE

Certified that the East End Public School running at ground & first floor building comprised of basement (vacant) ground & first floor at B-1/12, New Ashok Nagar, Delhi-110096, owned/occupied by East End Public School have complied with the fire prevention and fire safety requirements in accordance with the Circular No. 262-362 dated 17/01/2005 issued by the Director of Education and verified by the officer concerned of this department on 10/10/19 & 11/11/19 in the presence of Mr. Rahul (coordinator) of the school and found that the school building ground & first floor is fit for occupancy class B 'Educational Building' for with effect from 21/11/19 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on..... 21/11/19 .. at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

To,

1. The Principal,
East End Public School,
B-1/12, New Ashok Nagar, Delhi-110096.

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

