

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110 001**

No. F.6/DFS/MS/FH/2019/SZ/ 2183

Dated: 20/11/19

FIRE SAFETY CERTIFICATE

Certified that the Farm House at Kh. No. 242, 242(min), 235/2, 241 and 242/2 (min), Bhatti Village, Chatterpur Road, New Delhi comprised of ground floor only has already been issued FSC by this department vide letter F6/DFS/MS/FH/2016/SZ/1622 dated 03/11/2016. The Farm House was re-inspected by the officer concerned of this department on 09/11/16 in the presence of Mr. Benny (Manager) & found to have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class D "Assembly Building Farm House" with effect from 20/11/2019 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.. 20/11/19...at New Delhi by

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Assistant Engineer (Bldg)-II, SDMC, South Zone, Green Park, New Delhi.
2. Sh. Shivam Gupta, Kh. No. 242, 242(min), 235/2, 241 and 242/2 (min), Bhatti Village Chatterpur Road, New Delhi.

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. Any deviation with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
6. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."
8. This FSC is not valid for Temporary Structure & Pandal in the premises.

