

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/2019/ 2217

Dated: 26/11/19

FIRE SAFETY CERTIFICATE

Certified that the Om international School located at Kotla Vihar Ph-II, Near Village Shiv Mandir, New Delhi-110041, comprised of Ground & One Upper Floor only owned / occupied by Om international School, has already been issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2016/1412 dated 16/09/2016. The premises was re-inspected by the officer concerned of this department on 16/11/2019 in the presence of Smt. Sunita (Principal) and observed that Fire prevention and Fire Safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the Fire prevention and Fire Safety requirements in accordance with Director of Education Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and that the building / premises is fit for occupancy class Educational (Group-B) with effect from ...26/11/19.....for a period of 3 (three) years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule, 2010.

Issued on 26/11/19 at New Delhi by.

(DHARAMPAL BHARDWAJ)
DEPUTY CHIEF FIRE OFFICER.

Copy to :-

1. Smt. Sunita (Principal), Om international School, Kotla Vihar Ph-II, Near Village Shiv Mandir, New Delhi-110041.
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
3. The trained fire- fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

