

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/EH/SZ/2019/ 2225

Dated: 27/11/19

FIRE SAFETY CERTIFICATE

Certified that the **M/s. Pinjore Restaurant** running at Ground Floor of a building comprised of basement, ground plus three upper floors at Plot No. 1/4, Ground Floor, East Patel Nagar, New Delhi-110008, was granted NOC vide letter No. F.6/DFS/MS/EH/2010/2108 dated 16.07.2010 (in the name of M/s. Rice Bowl). The restaurant was re-inspected by the officer concerned of this department on 08/11/2019 in presence of Sh. Mayank Sabharwal & Mrs. Neha Paul (Owner/Occupier) and found that the owners have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class assembly (restaurant) with effect from 27/11/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 27/11/19 at New Delhi by.

W 26/X1
(Vipen Kental)
Chief Fire Officer
Ph.No. 011-23412225
82/11

Copy to:-

1. Sh. Mayank Sabharwal,
M/s. Pinjore Restaurant,
Plot No. 1/4, Ground Floor, East Patel Nagar,
New Delhi-110008.
2. The Deputy Health Officer,
North Delhi Municipal Corporation,
Karol Bagh Zone, New Delhi- 110005.

CONDITIONS

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. All the means of escapes /exits shall not be locked/bolted/blocked at any time for safe evacuation of the occupants in case of any emergency.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s Pinjore Restaurant, 1/4, Ground Floor, East Patel Nagar, New Delhi.
2. Type of Occupancy : Assembly (Restaurant)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/EH/2010/2108 dated 16.07.2010 (M/s Rice Bowl)
5. Fire Safety directives letter No : N/A
6. Date of inspection : 08.11.2019
7. Name of the Inspecting Officers : Shri Rajbir Kharb, ADO(SRD)
8. Name and designation of officers from the building side : Sh. Mayank Sabharwal, Mrs Neha Paul (Owner/Occupier)
9. Year of Construction : Before 2010
10. Applicant's letter No. : DHO/KBZ/2019/1492 dated 18.09.2019

The said restaurant is running at ground floor of a building comprised of basement, ground plus three upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per NBC/BBL	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Directly accessible from the road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	N/A	Located at GF	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	--	----	---
	g. Width of Corridor	2.0 mts	Opening at Hall	N/A
	h. Door Size	2.0 mts.	2.44, 1.51 & 1.10 mts	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements (other's property)	30 a/c per hour	N/A	N/A
	• Upper floors(Restaurant-GF)	12 a/c per hour	Exhaust fan provided	MR
5	Fire Extinguishers			
	• Total numbers	08	Provided	MR

	Types	CO ₂ , ABC type	Provided	
	IS marking	ISI marked	Provided	M
6	First-Aid Hose Reels.			
	Total numbers on G. floor (Rest.)	01	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N/A	Provided	N/A
	Location of Main Panel	N/A	GF	N/A
	Location of Repeater Panel	N/A	N/A	N/A
	Alternate source of power	N/A	Battery back up	N/A
	Hooters' Location	N/A	GF	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	N/A	N/A	N/A
	Entire Restaurant	N/A	Provided	N/A
	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-comer	N/A	Provided (100 mm)	N/A
	Number of hydrants per floor	N/A	Provided (01 No.)	N/A
	Hose Box	N/A	Provided (01 No.)	N/A
12	Yard Hydrants.			
	Total number of hydrants	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	Ground Level	---	---	---
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	Terrace level	-----	-----	-----
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 mts	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

Captive Water Storage for fire fighting.

	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	4000 lts	20,000 lts	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided (62 KVA)	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Two ABC type fire extinguisher found provided near elect. panel	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/EH/2010/2108 dated 16.07.2010 (M/s. Rice Bowl), renewal in the name and style of M/s Pinjore Restaurant under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Note: All the shortcomings pointed out by this department vide letter no. F.6/DFS/MS/GH/SZ/2019/801 dated 08.02.2019 have been complied with by the restaurant management.

DFA is put up for approval & signature please.

D.O. (SW)

Rajbir Kharb
Asstt. Div. Officer (S.Rd)