

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F6/DFS/MS/School/2019/NDZ/ 2187

Dated: 21/11/19

FIRE SAFETY CERTIFICATE

Certified that the M/s Raman Modern Public School running on ground plus one upper floor of the building comprised of ground plus two upper floors located at 338, Gali No-5, Bhagat Vihar, Delhi-110094, owned/occupied by M/s Raman Modern Public School was issued NOC vide letter No. F6/MS/DFS/MS/2009/3501 dated 20/11/09. The school building was re-inspected by the officer concerned of this department in presence of Mr. Rajpal Sharma, Manager of the school and found that the school have deemed complied with the fire prevention and fire safety requirements in accordance with circular No. 262-362 dated 17/01/2005 issued by Director of Education and observed that school building ground and first floor is fit for occupancy class "B" 'Educational Building' with effect from ...21.11.19. for a period of **three** years, subject to conditions, printed below.

Issued on...21/11/19.....at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer

To,

The Manager,
M/s Raman Modern Public School at 338, Gali No-5, Bhagat Vihar, Delhi-110094

Copy:-

The Dy. Director of Education
B-Block, Yamuna Vihar, North-East, Delhi-110053

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : Raman Modern Public School,
338, Gali No-5, Bhagat Vihar, Delhi-110094
2. Building is comprised of :Ground plus two upper floors
(School is running on ground plus first floor only)
3. Type of Occupancy :Educational
4. Type of Case :Renewal
5. Details of Previous NOC letter :F6/MS/DFS/MS/2009/3501 dated-20/11/09 (for G+1)
6. Fire Safety direction letter No :Circular 262-362 dated 17/01/2005 issued by DoE
7. Date of Inspection :23/10/2019
8. Name of the Inspecting officers :DO F. Brown
9. Name and designation of Officer from the building side : Mr. Rajpal Sharma (Manager)
10. Year of Construction :2006
11. Applicant's letter No :Nil, Dated- 29/07/19

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 mtr.	4.50 mtr.	M (Old accepted)
		N/A	N/A	N/A
		N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	01 nos N/A	02 nos N/A	MR N/A
	b. Width of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	1.50 mtr. N/A	1.30 mtr. & 0.78 mtr N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of Continuous Staircases to Terrace	01 No.	01 No.	MR
	e. Width of Corridor	1.50 mtr.	1.50 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> Basement Upper floor 	N/A N/A	N/A N/A	N/A N/A
05.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	04 nos. ABC /CO ₂ ISI marked	08 nos. ABC /CO ₂ ISI marked	MR MR MR

06	First-Aid-Hose Reels.			
	• Total numbers on each floor	01 No.	01 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of Main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto Starting /Manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	220 Lpm.	220 Lpm.	MR
	• Head of the pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	2500 Ltr.	2500 Ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A

NLS

17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the circular No. 262-362 dated 17/01/2005, it is recommended to renew Fire Safety Certificate.

Signature of the Inspecting Officer
Name - F. Brown
Designation - D.O (ED)

Dy. CFO (NDZ)

F. T. pleast

1/11/11

DO(E)

F.T. letter is prepared and put up for signature

DY. CFO/NDZ

1/11/11

15/11

M.S. ell