

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/2019/NDZ/ 2209

Dated: 25/11/19

FIRE SAFETY CERTIFICATE

Certified that the St. Andrews Scot School at 11/56 West Azad Nagar Delhi-51, owned/occupied by St. Andrews Scot School, Comprised of ground plus one upper floor was granted FSC vide letter **F6/DFS/MS/School/2016/1595 dated 27/10/16**. The school building was inspected by the officer concerned of this department on 13/11/19 in the presence of **Mr. Jagdish Sondhi (Manager)** of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no.262-362 Dated 17.01.2005 issued by the Director of Education and ground & first floor of building is fit for occupancy class B "Educational Building" with effect from ...25/11/19..., for a period of **three** years, subject to conditions printed overleaf.

Issued on25/11/19..... at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

OK

To,

The Manager,
St. Andrews Scot School, 11/56 West Azad Nagar Delhi-51

Copy to:-

1. The Director of Education,
East Delhi Municipal Corporation,
419, Udyog Sadan, Patparganj Industrial Area, Delhi-92.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept unlocked & free from any obstruction.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate cannot be treated in any case for regularizations of unauthorized construction or Alteration if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule' of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

