

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2019 / *w2/2244*

Dated: *28* / *11* / 2019

FIRE SAFETY CERTIFICATE

Certified that the **Maharishi Dayanad Public School** located at **Iswar Colony Bawana Delhi-110039** comprised of **Ground and 01 upper floors & one servant room on terrace** owned/occupied by owned/ occupied by **Maharishi Dayanad Public School** have complied with the fire prevention and safety requirements in accordance with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on 06.11.2019 in the presence of **Smt. Sarita Rani (Principal)** and that the building/premises is fit for occupancy Group B Educational for ground and first floor only with effect from *28.11.19* for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on *28.11.19* at New Delhi by.

W 28/11
(Vipin Kental)
Chief Fire Officer
Ph:-011-23412225

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Manager, Principal, Dayanand Public School, Ishwar Colony, Bawana, Delhi-110039.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

SPECTION REPORT

1. Name & address of the building : Maharishi Dayanand Public School, Ishwar Colony, Bawana, Delhi-110039.
2. Type of Occupancy : Educational
3. Type of Case : New Case 01 block- (Ground + 01 upper floor only)& one servant room on terrace
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : Director of Education Letter dated 01.03.2011
6. Date of inspection : 06.11.2019
7. Name of the Inspecting Officers : Rajesh Kumar, ADO (RN)
8. Name and designation of officers from the building side : Smt. Sarita Rani (Principal)
9. Year of Construction : Since 2005
10. Applicant's letter No. : MDPS/19-20/172 Dated 23.09.2019

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.30m & 1.05m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor			
f. Door Size	1.0m	1.00 m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA

