

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/EH/2019/SZ/ 2233

Dated: 27/11/19

FIRE SAFETY CERTIFICATE

Certified that the Munde Distributors LLP (Restaurant) located at Ground Floor, RSM02, Plot No.1 Sector- 13 Dwarka, New Delhi, of a building comprised of Three basements, ground plus three upper floors, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service rules 2010 and verified by the officer concerned of Fire Service on 11.11.2019 in presence of Sh. Ashish Sharma (Manager) and that the premises is fit for occupancy 'Assembly building' Group-D (Restaurant) with effect from 27.11.19..... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed over leaf. The Reliance Ambit Trade Mall Where restaurant is located has already been a valid Fire Safety Certificate issued by this department vide letter no.F6/DFS/MS/Mercantile/2018/SZ/1222 dated 24.5.2018.

Issued on 27.11.19..... at New Delhi by

ae (Vipin kental)
Chief Fire Officer

Copy to:-

1. The DHO, Najafgarh Zone, SDMC Public Health Department, Room No. 408, Zonal Officer Building, Near Dhansa stand, New Delhi.
2. The Additional Commissioner of Police, Licensing Unit, 1st Floor, Police Station, Defense Colony, New Delhi,
3. The Authorized Signatory, the Munde Distributors LLP (Restaurant) at Ground Floor, RSM02, Plot No.1 Sector- 13 Dwarka, New Delhi

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

