

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE : NEW DELHI - 110001

NO. F.6/DFS/MS/EH/2019/NDZ/ 2235

Dated: 28/11/19

FIRE SAFETY CERTIFICATE

Certified that **The Vinayak Restaurant running at ground floor of building** comprised of **Ground + 2 Upper Floors**, at 1450, G/F, East Jyoti Nagar, Loni Road, Shahdara, Delhi- 93 have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service rules, 2010. The restaurant (eating house) was Inspected by the offices concerned of fire service on **09-10-2019 & 20-11-2019** in the presence of **Sh. Narender (Manager)** and found that the ground floor of the building is fit for occupancy class **Group- D**, Restaurant (Eating House) with effect from 28/11/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, and subject to compliance of the conditions under rule 38 of the Delhi Fire service rule 2010. printed overleaf.

Issued on 28/11/19 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.), Police Station, Defence Colony, New Delhi.
2. Sh. Narender (Manager), M/S Vinayak Restaurant at 1450, G/F, East Jyoti Nagar, Loni Road, Delhi-93.

Following fire safety directives may be adhered to :-

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and lapse rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regard to construction, electric installation etc may be got verified from the concerned authorities.
5. Basement shall be used as per NBC / BBL 1983.
6. This NOC may not be treated in any case for regularizations of unauthorized construction if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi fire service 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The access around the blocks as submitted in the plans submitted by Principal Architect Design Plus shall be kept clear of any obstruction for free movement of fire units in case of emergency.
9. The owner / occupier shall apply for renewal of this fire safety certificated to the director in Form 'the [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to it expiry.

