

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/2019/SZ / 2260

Dated: 4/12/19

FIRE SAFETY CERTIFICATE

Certified that the **Community Facility (CF)** at Residential Cum Training Complex for SPG, Plot No. 21, Sector 21, Dwarka, New Delhi-110077, comprised of ground plus five upper floors owned/occupied by SPG Govt. of India have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire Service Rules, 2010 and verified by the officers concerned of Delhi Fire Service on 25.10.2019 & 05.11.2019 in the presence of Sh. Rajeev Kumar (Dy. General Manager (Engg.)-NBCC & Sh. Ajay Kumar-SO-I (SPG) and that the building is fit for Mixed occupancy (**Storage, Residential & Assembly**) with effect from.....4.12.19..... for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on.....4.12.19..... at New Delhi by

(Atul Garg)
Director

Ph:- 011-23414000
9/c

Copy to: -

1. The Joint Director, DDA, Vikas Sadan INA, New Delhi.
2. The Assistant Inspector General (Works), SPG Complex, Sector-8, Dwarka, New Delhi-110077.
3. The Dy. General Manager (Engg.) NBCC (India) Ltd, SPG Complex, Dwarka, New Delhi-110077.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. Access roads for movement of fire units in case of emergency all around the building shall be kept free from any hindrance.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

