

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/School/2019/SZ/ 2256

Dated: 04/12/19

**FIRE SAFETY CERTIFICATE**

Certified that the Lakshya Deep Public School located at L-1003, Gali No.15, Sangam Vihar, New Delhi-110080 comprised of ground plus one upper floor was issued NOC by this department vide letter No. F6/DFS/MS/School/2016/SZ/804 Dated 19/05/2016. The premises was re-inspection by officer concerned by this department on 15/11/2019 in the presence of Mr. Yatender Sharma (Manager) of the school and found that fire prevention and fire safety requirements have deemed complied in accordance with Circular No. 262-362 dated 17/01/05 issued by Education Directorate, Govt. of NCT of Delhi, Old Secretariat, New Delhi and that the premises fit for occupancy class Education Building, Group-B as above with effect from the date of issue of this certificate for period of three years subject to compliance of conditions mentioned below.

Issued on 04/12/19 at New Delhi by

  
(Rajesh Panwar)  
Dy. Chief Fire Officer  
Tel. 011-26189168  
AZ etc

Copy to: -

1. The Principal, Lakshya Deep Public School, L-1003, Gali No.15, Sangam Vihar, New Delhi-110080.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1	Name & Address of the Building	Lakshya Deep Public School, L-1003, Gali No.15, Sangam Vihar, New Delhi-110080		
2	Type of Occupancy	Educational "Group-B" (School)		
3	Building Comprised of	Ground + 01 upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2016/SZ/804 Dated 19/05/2016		
6	Fire Safety Directives Letter No	DOE Circular 262-232 dated 17/01/2005		
7	Date of Inspection	15/11/2019		
8	Name of the Inspecting Officers	Avtar, ADO (MR)		
9	Name & Designation of Officers from the building side	Mr. Yatnder Sharma (Manager)		
10	Year of construction	2005		
11	Applicant letter No.	LDPS/07/2019-20 dated 25/09/2019		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>As Per Old NOC</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	• Road width	6m	Provided	MR
	• Gate width	4.5m	Provided	MR
	• Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width, type &amp; arrangement of exits</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors	02Nos	02 Nos	MR
	➤ Basement floor	N/A	N/A	N/A
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.5 m/0.75m	1.13m, & 0.75m	MR
	➤ Basement floor	N/A	N/A	N/A
	<b>c) Protection of exits</b>			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	<b>d) No. of continuous staircase to terrace</b>	One	One	MR
	<b>e) Width of corridor</b>	N/A	N/A	N/A
	<b>f) Door size</b>	1mtr	1mtr	MR
<b>3</b>	<b>Compartmentation.</b>			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	NA	NA	NA
<b>4.</b>	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	NA	MR
	• Upper floors	12 ACPH	N/A	N/A
<b>5.</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	08 No's	08 No's	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR






- N/10 -

19.	<b>Fire Control Room.</b> <ul style="list-style-type: none"><li>• Detector System Panel.</li><li>• Flow Switch Panel.</li><li>• PA system Panel.</li><li>• Battery backup</li><li>• Building floor plan</li></ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	Required	01 ABC type fire extinguisher is provided near elect. panel	N/A

The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE circular, FSC issued vide letter No F6/DFS/MS/School/2016/SZ/804 Dated 19/05/2016 renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

Accordingly, DFA is put up for approval and signature please.

  
Signature of the Inspecting Officer  
Name: Avtar  
Designation: ADO (MR)

~~DO (SD)~~

~~Line~~  
20/11

~~DCFO (SZ)~~


~~Signature~~  
21/11

~~DO (RM)~~

~~CEO~~  
22/11

~~ADO (MR)~~

F.T letter is put up for sign. please

  
25/11/19

~~DCFO (SZ)~~

~~Signature~~  
29/11

