

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2019/SZ/ 2259

Dated: 09/12/19

**FIRE SAFETY CERTIFICATE**

Certified that the SDMC Primary Co-Ed. School located at Kilokri Village, New Delhi-110014 comprised of ground plus one upper floor only was issued FSC by this department vide letter No. F6/DFS/MS/School/2016/SZ/285 Dated 19/02/2016. The premises was re-inspection by officer concerned by this department on 15/11/2019 in the presence of Ms. Sheema Wasif (Principal) of the school and found that fire prevention and fire safety requirements have deemed complied in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Education Directorate, Govt. of NCT of Delhi, and that the premises fit for occupancy class Education Building, Group-B as above with effect from the date of issue of this certificate for period of three years subject to compliance of conditions mentioned below.

Issued on 09/12/19 at New Delhi by

(Rajesh Panwar)  
Dy. Chief Fire Officer  
Tel. 011-26189168  
RZ dc

Copy to: -

1. The Principal, SDMC Primary Co-Ed. School, Kilokri Village, New Delhi-110014.
2. Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT


1	Name & Address of the Building	SDMC Primary Co-Ed. School, Kilokri Village, New Delhi-110014		
2	Type of Occupancy	Educational "Group-B" (School)		
3	Building Comprised of	Ground Plus One Upper floor Only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2016/SZ/285 Dated 19/02/2016		
6	Fire Safety Directives Letter No	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 1.03.2011		
7	Date of Inspection	15/11/2019		
8	Name of the Inspecting Officers	Avtar, ADO (MR)		
9	Name & Designation of Officers from the building side	Ms. Sheema Wasif (Principal)		
10	Year of construction	2009		
11	Applicant letter No.	Outdoor Dairy No.22538 dated 14/10/2019		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	As Per Old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6m	6m ✓	MR
	• Gate width	4.5m	Provided ✓	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits			
	a) Number of Staircase			
	➤ Upper floors	02Nos	02Nos ✓	MR
	➤ Basement floor	N/A	N/A	N/A
	b) Width of Staircase			
	➤ Upper floors	1.5m/0.75m	1.50m each ✓	MR
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	01no	Provided	MR
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	1m	1m ✓	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	30 ACPH	NA	NA
	• Upper floors	12 ACPH	NA	NA
5.	Fire Extinguishers.			
	• Total numbers	08 No's	08 No's ✓	MR
	• Types	ABC	ABC	MR
	• ISI Marking	ISI marked	Provided	MR



N/111

6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	N/A	N/A	N/A
	• Length of hose-reel hose.	N/A	N/A	N/A
	• Nozzle Diameter	N/A	N/A	N/A
7	<b>Automatic fire detection &amp; alarming system</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	<b>MOEFA</b>	N/A	N/A	N/A
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby pump head.	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	N/A	N/A	N/A
	➤ Head of pump.	N/A	N/A	N/A
	➤ Power supply.	N/A	N/A	N/A
	➤ Auto starting of pump.	N/A	N/A	N/A
14.	<b>Captive water storage for Fire Fighting.</b>			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	N/A	N/A	N/A
15.	<b>Exit Signage.</b>	Required	Provided	MR

N/12

16.	<b>Provisions of Lifts.</b>			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	<b>Standby Power Supply</b>	N/A	N/A	N/A
18.	<b>Refuge Area</b>			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	<b>Fire Control Room.</b>			
	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			N/A
<p>The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection</p> <p>Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE circular, FSC issued vide letter No. F6/DFS/MS/School/2016/SZ/285 Dated 19/02/2016 renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended</p> <p>Accordingly, DFA is put up for approval and signature please.</p> <p style="text-align: right;">   19/11/19  Signature of the Inspecting Officer  Name: Avtar  Designation: ADO (MR) </p>				

DO (SD)

Line  
28/11

DCFO (S2)

21/11

22/11

DO (MR)

ADO (MR)

F.T letter is put up for sign. please

Avtar

