

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI

No.F6/DFS/MS/WZ/2019/ 2276

Dated: 09/12/2019

FIRE SAFETY CERTIFICATE

Certified that the **Cinepolis (formerly known as Fun Cinemas)** located at TDI Mall, Moti Nagar, New Delhi – 110015 in a building comprised of 2 Basement + Ground + 3 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/Cinema/2016/WZ/1740 dated 02/12/2016, FSC to the Mall is issued vide letter no.F6/DFS/MS/WZ/2019/1927 Dated 10.10.2019. The premises was re-inspected by the officer concerned of this department on 13/11/2019 in the presence of Mr. Shashank Rastogi (AM) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly Building" Group D with effect from 09/12/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on09/12/19.... at New Delhi by.

(Atul Garg)
Director

Ph:- 011-23414000

Copy to:

1. The Addl Commissioner of Police (Licensing), 1st Floor, Police Station, Defence Colony, New Delhi..
2. The SDM (HQ-I/DDMA) GNCT of Delhi, Rajouri Garden, Ext. New Delhi – 110027
3. Mr. Shashank Rastogi (AM) **Cinepolis** (formerly known as Fun Cinemas) TDI Mall, Moti Nagar, New Delhi – 110015

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : **Cinepolis (formerly known as Fun Cinemas)**
located at TDI Mall, Moti Nagar, New Delhi – 110015
2. Type of Occupancy : Assembly (2 Basement + Ground + 3 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/Cinema/2016/WZ/1740 dated 02/12/2016
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2002/1040 dated 02-07-02 & F6/DFS/Cinema/2004/BP/370 dated 16-02-04
6. Date of inspection : 13/11/2019
7. Name of the Inspecting Officer : Udai vir Singh (ADO/WP)
8. Name and designation of Officer
from the building side : Mr. Shashank Rastogi (AM)
9. Year of Construction : 2005
10. Applicant's letter No. : 1685/Addl.CP/Lic.(Cinema), dated 30/10/19

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	20 m 6 m 6 m	Provided Provided Provided	MR MR MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases <ul style="list-style-type: none"> • Upper floors • Basements b. Width of staircases <ul style="list-style-type: none"> • Upper floors • Basements c. Protection of exits <ul style="list-style-type: none"> • Fire check door • Pressurization d. No of continuous staircase to terrace	05 nos. NA 2x2 mtr 3x1.5 mtr NA NA Required Required NA Old Case Old Case	05 no. Provided NA 1x136 cm, 1x186 cm 1x186 cm, 1x192 cm 1x141cm Provided NA Provided Provided NA Old Case Old Case	MR NA MR MR MR MR MR MR MR MR
3.	Compartmentation	Common with mall		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required Required Required Required Required	Provided Found Sealed Provided Found Provided Provided	MR MR MR MR MR

4.	Smoke managements System	Common with mall		
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	03 nos. each Audi	03 nos each Audi Provided	MR
	• Types	ABC, CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	02 no. each Audi	02 no. in each Audi Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required at Mall	Provided	M.R
	• Upper Floor	Required at Cinema	Provided	M.R
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants	Common with mall		
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants	Common with mall		
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements	Common with mall		
	• Ground Level			
	• Discharge of main pump	2850 lpm	Provided	MR
	➤ Head of main pump	60 m	Provided	MR
	➤ Number of main pumps	2	Provided	MR
	➤ Jockey pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	60 m	Provided	MR
	➤ Standby Pump out put	2850 lpm	Provided	MR
	➤ Standby Pump Head	60 m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NR	NR	NR
	➤ Head of the pump	NR	NR	NR
	➤ Power supply	NR	NR	NR
	➤ Auto starting of pump	NR	NR	NR
14.	Captive water Storage for fire fighting	Common with mall		
	• Under ground tank capacity	1,50,000 litres	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20, 000 litres	Provided	MR

15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	Provided	NA
	➤ Pressurization of lift lobby	NA	Provided	NA
	➤ Communication in lift Car	NA	Provided	NA
	➤ Fireman's Grounding Switch	NA	Provided	NA
	➤ Lift Signage	NA	Provided	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	Provided at Terrace	NA
	➤ Location	NA	Provided	NA
19.	Fire control room			
	➤ Detector system panel	NA	Provided	NA
	➤ Flow Switch Panel	NA	Provided	NA
	➤ PA System Panel	NA	Provided	NA
	➤ Battery backup	NA	Provided	NA
	➤ Building Floor Plans	NA	Provided	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	Provided	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. **F6/DFS/MS/Cinema/2016/WZ/1740 dated 02/12/2016** renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name Uday Vir Singh

Designation ASO/WD

DGTW 15/11/19
DGTW
CFO 18/11/19
beentat 22/11/19
26/11/19