

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO.F6/DFS/MS/School/2019/SZ/ 2273

Dated:

09/12/19

FIRE SAFETY CERTIFICATE

Certified that the Dwarka Public School located at 12/6, Patel Garden, Palam Road, Kakrola Chowk, New Delhi-110059, comprised of ground plus one upper floor, was issued Fire Safety Certificate vide this department letter no. F6/DFS/MS/School/2016/SZ/869 dated 26.5.2016. The said school building was re-inspected by the officer concerned of this department on 28.11.2019 in presence of Smt. Harindar Sood (Academic Coordinator) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi letter no. Estate/CC/Fire Safety/2011/3298 to 3398 Dtd. 1.3.2011 and that the building is fit for occupancy class B "Educational building" with effect from.....09/12/19, for a period of **three** years subject to compliance of the conditions printed overleaf.

Issued on09/12/19..... at New Delhi by


(Rajesh Panwar)
Dy.Chief Fire Officer

Copy to:-

1. Director (Education), GNCT of Delhi, old Secretariat, New Delhi-110054.
2. Sh. Bijender Gahlot, Dwarka Public School located at 12/6, Patel Garden, Palam Road, Kakrola Chowk, New Delhi-110059.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

