

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No.

F6/DFS/MS/2019/Audi/NDZ/2319

Dated:

13/12/19

**FIRE SAFETY CERTIFICATE**

Certified that the M.P.C.U. Shah Auditorium, 02, Raj Niwas Marg, Delhi-54, comprised of basement (below the lobby part of auditorium), ground plus one upper floor was granted Fire Safety Certificate by this department vide Letter No- F.6/DFS/MS/2017/Audi/NDZ/621 dated 02.05.17. The premises was re-inspected by the officer concerned of this department on 19.11.2019 in the presence of Supervisor and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rule, 2010 and found that the building having B+GF+FF is fit for occupancy class "Assembly building" with effect from ...13/12/19... renewed for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 subject to conditions printed below.

Issued on...13/12/19...at New Delhi by

  
(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service  
Tel: 011-23414262

Copy to:-

1. The Addl. Commissioner of Police: Licensing,  
1<sup>st</sup> Floor, P S Defence Colony, New Delhi
2. The Manager,  
M.P.C.U. Shah Auditorium, 02, Raj Niwas Marg, Delhi-54

Condition for the validity of fire safety certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building : M.P.C.U. Shah Auditorium, 02, Raj Niwas Marg, Delhi-54
2. Building is comprised of : basement (below the lobby part of auditorium) + ground +01 upper floor
3. Type of Occupancy : Assembly building
4. Type of Case : Renewal
5. Details of Previous FSC : F.6/DFS/MS/2017/Audi/NDZ/621 dated 02.05.17
6. Fire Safety direction letter No : NA
7. Date of Inspection : 19.11.2019
8. Name of the Inspecting Officers: : Rajinder Atwal (DO), Rajesh Kumar Shukla (ADO),
9. Name of the designation of Officer from the building side : Supervisor
10. Year of Construction : 1976
11. Applicant's letter No : DGS No. 089/32/2019-20 dated 31.05.2019

S.No	Minimum Standards on fire Prevention and Fire Safety U/R 33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	6 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	01 no.	01 no.	MR (old case)
	Basement	01 no.	01 no.	MR
	B. Width of Staircases			
	Upper Floor	1.5 m	1.5 m	MR
	Basement	1.5 m	1.5 m	MR
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	1 no.	1 no.	MR
	g. Width of Corridor	NA	NA	NA
	h. Door Size	1.5 m	1.5 m	MR
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	12 a/c per hr	Provided	MR





5.	Fire Extinguisher			
	Total numbers types IS marking	06 no.	24 no.	MR
		CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
		ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	03 no.	03 no. (02 no of ground floor & 01 no. at 1 <sup>st</sup> floor	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	20 mm	20 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters's location	N.A.	NA	NA
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler on stage	Required	Provided	MR
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	01 no.	01 no.	MR
	Hose Box	01 no.	01 no.	MR
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the Pump	45 m	45 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	50,000 Liters	50,000 Liters	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	16,000 Liters	16,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the auditorium were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no F.6/DFS/MS/2017/Audi/NDZ/621 dated 02.05.17 is recommended for renewal.

Signature of the Inspecting Officer

Name Rajinder Atwal

Designation DO (CC)

Signature of the Inspecting Officer

Name Rajesh Kumar Shukla

Designation ADO (SPM)

DY CFO (NDZ)

*F.T. plan*  
*4/12*  
*m.f. cell*  
*29/11*