

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/WZ/2019/*school/2324*

Dated: *13/12/2019*

FIRE SAFETY CERTIFICATE

Certified that the building of **Nagar Nigam Prathmik Bal Vidyalaya (I & II Shift)**, located at **Chaukhandi Old, New Delhi - 110018**, comprised ground plus one upper floor, owned and occupied by Nagar Nigam Prathmik Bal Vidyalaya (I & II Shift) was issued FSC vide Letter No. F6/DFS/MS/SCHOOL/2016/WZ/1648 Dated 08/11/2016. The premises was re inspected by the officer concerned of this department on 02/12/2019 in the presence of **Smt. Renu (Incharge)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298 – 3398 Dated 17-01-2011 and that the premises is fit for occupancy class "Educational" Group B with effect from *13/12/19* for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *13/12/19*..... at New Delhi by.

(Signature)
(Dharampal Bhardwaj)
DY. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Principal, Nagar Nigam Prathmik Bal Vidyalaya (I & II Shift), Chaukhandi Old, New Delhi – 110018
2. Director of Education, Old Secretariat, Delhi-110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. Basement shall be used as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: **Nagar Nigam Prathmik Bal Vidyalaya (I & II Shift)**, Located at **Chaukhandi Old, New Delhi - 110018.**
2. Type of Occupancy : Educational (Ground + 1 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2016/WZ/1648
Dated 08/11/2016
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 1-3-2011
6. Date of inspection .02/12/2019
7. Name of the Inspecting Officer : Udaivir Singh ADO (WP)
8. Name and designation of Officer
from the building side : Smt. Renu (Incharge)
9. Year of Construction : 1962
10. Applicant's letter No. : Nil dated 01/11/2019

Area of School-4626 sqm
Covered Area- 758.50 sqm
Class Room- 18
Total Students -439

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE 3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	<div>Accessible</div> <div>Accessible</div> <div>NA</div>	<div>06m</div> <div>350cm</div> <div>NA</div>	<div>MR</div> <div>MR</div> <div>NA</div>
2.	Number, width, Type & Arrangements of exits			
	<div>a. Number of staircases</div> <ul style="list-style-type: none"> Upper floors Basements <div>b. Width of staircases</div> <ul style="list-style-type: none"> Upper floors Basements <div>c. Protection of exits</div> <ul style="list-style-type: none"> Fire check door Pressurization <div>d. No of continuous staircase to terrace</div> <div>e. Width Of Corridor</div> <div>f. Door Size</div> <div>g. Hall (250 Students)</div>	<div></div> <div>2</div> <div>NA</div> <div></div> <div>2X1.5m</div> <div>NA</div> <div></div> <div>NA</div> <div>NA</div> <div>1</div> <div>1.5m</div> <div>1 m</div> <div>NA</div>	<div></div> <div>Provided</div> <div>NA</div> <div></div> <div>Ix173cm & Ix163 cm</div> <div>NA</div> <div></div> <div>NA</div> <div>NA</div> <div>Provided</div> <div>225 cms</div> <div>2x110 cms</div> <div>NA</div>	<div></div> <div>MR</div> <div>NA</div> <div></div> <div>MR</div> <div>NA</div> <div></div> <div>NA</div> <div>NA</div> <div>MR</div> <div>MR</div> <div>NA</div>
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	<div>NA</div> <div>NA</div> <div>NA</div> <div>NA</div> <div>NA</div>	<div>NA</div> <div>NA</div> <div>NA</div> <div>NA</div> <div>NA</div>	<div>NA</div> <div>NA</div> <div>NA</div> <div>NA</div> <div>NA</div>

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	4 nos.	6 Provided	MR
	• Types	ABC	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No. F6/DFS/MS/SCHOOL/2016/WZ/1648 Dated 08/11/2016 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
Name Uday Vir Singh
Designation ADOP

Signature of the Inspecting Officer
Name
Designation

ADP/W

Please see 2a.

3/12/19

ADOP

Sir necessary correction is done in nothing.

3/12

ADP/W

3/12/19