

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/DMRC/2019/WZ/ 2268

Dated: 05/12/19

FIRE SAFETY CERTIFICATE

Certified that the **Delhi Metro Rail Corporation** located at **Paschim Vihar (West) Metro Station** (Elevated), Paschim Vihar (West), Delhi-110063 comprised of Ground, 1st Floor (Concourse) & 2nd Floor (Platform Level) was issued FSC vide letter no. F6/DFS/MS/2010/600 dated 02/03/2010. The premises was re inspected by the officer concerned of this department on 15-11-2019 in the presence of Mr. Sanyam Jain (AM/Fire) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building / premises is fit for the occupancy class "Assembly" Group D Sub Division D - 7 with effect from 05/12/19... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05/12/19 at New Delhi by.

W
27/12/19

(VIPIN KENTAL)
CHIEF FIRE OFFICER.

Copy to:

1. Sh. Rajesh Agrawal (JGM/E&M), AM/Fire, DMRC, Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi - 110001.

92

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

