

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/Cinema/WZ/2019/ 2274

Dated: 09/12/2019

**FIRE SAFETY CERTIFICATE**

Certified that the PVR Ltd., (Audi 1 - 6), located at Pacific Mall, Subhash Nagar, New Delhi in a building comprised of 02 basement + ground+05 upper floors was issued FSC vide Letter No. F6/DFS/MS/Cinema/2016/1775 dated 08/12/16. FSC to the mall is issued vide letter no. F6/DFS/MS/2017/WZ/577 dated 21-04-2017. The premises was re-inspected by the officers concerned of this department on 04-12-2019 in the presence of Sh. Virpal and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly Building" Group D with effect from 09/12/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/12/19 at New Delhi by.

(Atul Garg)  
Director

Delhi Fire Service

Copy to:

1. Sh. Sunil Kumar Bhatnagar, PVR Ltd., (Audi 1 - 6), Pacific Mall, Subhash Nagar, New Delhi
2. The SDM (HQ-I/DDMA) GNCT of Delhi, Old Middle School Complex, Rampura, Delhi - 110035

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

- Nagar, New Delhi
2. Type of Occupancy : (Assembly D – 6)
  3. Type of Case : Renewal
  4. Details of previous NOC : F6/DFS/MS/Cinema/2016/1775 dated 08/12/2016
  5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2008/961 dated 07-04-2008 for the Mall
  6. Date of inspection : 04/12/2019
  7. Name of the Inspecting Officer : ADO (WO)
  8. Name and designation of Officer  
from the building side : Sh. Vir Pal
  9. Year of Construction : 2010
  10. Applicant's letter No. : Nil dated 05/11/2019

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	60 m	Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	04nos	04 nos Provided	M/R
	• Basement	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m	1x140 cm, 1x145cm, 1x142 cm, varying 1x225/170 cm Provided	MR
	• Basement	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Required	Provided	M.R.
	e. Width of Corridor	NA	NA	NA
	f. Door size	3 exits in Audi 1 to 4 2 exits in Audi 5 & 6	Provided	M.R.
3.	<b>Compartmentation. Common With Mall</b>			
	• Fire check door	Required	Provided	M.R.
	• Sealing of electrical shafts	Required	Provided	M.R.
	• Fire Rating of shaft door	Required	Provided	M.R.
	• Water Curtain	Required	Provided	M.R.
	• Fire Dampers	Required	Provided	M.R.
4.	<b>Smoke Management System. Common With Mall</b>			
	• Basements	30 a/c per hour	Provided	M.R.
	• Upper floors	12 a/c per hour	Provided	M.R.
5.	<b>Fire Extinguishers</b>			
	• Total numbers	03 nos. each Audi	Provided 03 nos. each Audi	M.R
	• Types	ABC & CO <sub>2</sub>	Provided	M.R.
	• IS marking			



6.	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	02 in Audi 1 to 4 01 in Audi 5 & 6 30 m required	02 in Audi 1 to 4 01 in Audi 5 & 6 Provided	M.R M.R
	• Length of hose reel hose	5 mm	Provided	M.R
	• Nozzle diameter			
7.	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Smoke & Beam detector	Provided	M.R
	• Location of Main Panel	Ground floor	Provided	M.R
	• Location of Repeater Panel	Ground floor	Provided	M.R
	• Alternate source of power	Required	Provided	M.R
	• Hooter's Location	Required	Provided	M.R
8.	<b>MOEFA</b>	Required	Provided	M.R
9.	<b>Public Address System</b>	Required	Provided	M.R
10.	<b>Automatic Sprinkler system</b>			
	• Basement	Required at Mall	Provided	M.R
	• Upper Floor	Required at Cinema	Provided	M.R
	• Sprinkler above false ceiling	Required	Provided	M.R
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	02 in Audi 1 to 4 01 in Audi 5 & 6	02 in Audi 1 to 4 01 in Audi 5 & 6	M.R.
	• Number of hydrants per floor	Required	Provided	M.R
	• Hose Box	10 Required	10 Provided	M.R
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants	13 of Mall	13 Provided	M.R
	• Hose Box	13 of Mall	13 Provided	M.R
13.	<b>Pumping Arrangements. Common with Mall</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	2850 lpm	2850 lpm Provided	MR
	➤ Head of Main pump	60 m	60 m Provided	MR
	➤ Number of main pumps	2	2 Provided	MR
	➤ Jockey Pump out put	180 lpm	180 lpm Provided	MR
	➤ Jockey pump head	60 m	60 m Provided	MR
	➤ Standby pump out put	2850 lpm	2850 lpm Provided	MR
	➤ Standby pump Head	60 m	60 m Provided	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	<b>Terrace level</b>			
	➤ Discharge of pump	450 lpm	450 lpm Provided	MR
	➤ Head of the pump	30 m	30 m Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting. Common With Mall</b>			
	<b>Underground tank capacity</b>	02 lac litrs	02 lac litrs Provided	M.R
	➤ Draw off connection			



7.	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Smoke & Beam detector	Provided	M.R
	• Location of Main Panel	Ground floor	Provided	M.R
	• Location of Repeater Panel	Ground floor	Provided	M.R
	• Alternate source of power	Required	Provided	M.R
	• Hooter's Location	Required	Provided	M.R
8.	<b>MOEFA</b>	Required	Provided	M.R
9.	<b>Public Address System</b>	Required	Provided	M.R
10.	<b>Automatic Sprinkler system</b>			
	• Basement	Required at Mall	Provided	M.R
	• Upper Floor	Required at Cinema	Provided	M.R
	• Sprinkler above false ceiling	Required	Provided	M.R
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	02 in Audi 1 to 4 01 in Audi 5 & 6	02 in Audi 1 to 4 01 in Audi 5 & 6	M.R.
	• Number of hydrants per floor	Required	Provided	M.R
	• Hose Box	10 Required	10 Provided	M.R
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants	13 of Mall	13 Provided	M.R
	• Hose Box	13 of Mall	13 Provided	M.R
13.	<b>Pumping Arrangements. Common with Mall</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	2850 lpm	2850 lpm Provided	MR
	➤ Head of Main pump	60 m	60 m Provided	MR
	➤ Number of main pumps	2	2 Provided	MR
	➤ Jockey Pump out put	180 lpm	180 lpm Provided	MR
	➤ Jockey pump head	60 m	60 m Provided	MR
	➤ Standby pump out put	2850 lpm	2850 lpm Provided	MR
	➤ Standby pump Head	60 m	60 m Provided	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	<b>Terrace level</b>			
	➤ Discharge of pump	450 lpm	450 lpm Provided	MR
	➤ Head of the pump	30 m	30 m Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting. Common With Mall</b>			
	<b>Underground tank capacity</b>	02 lac litrs	02 lac litrs Provided	M.R
	➤ Draw -off connection	Required	Provided	M.R
	➤ Fire service inlet	Required	Provided	M.R
	➤ Access to tank	Required	Provided	M.R
	➤ Overhead Tank Capacity	20,000 ltrs	20,000 ltrs provided	M.R.
15	<b>Exit Signage.</b>	Required	Provided	M.R.

16.	Provision of			
	• Pressurization of Lift Shaft	Required	Provided	M.R
	• Pressurization of Lift lobby	Required	Provided	M.R
	• Communication In lift Car	Required	Provided	M.R
	• Fireman's Grounding Switch	Required	Provided	M.R
	• Lift Signage	Required	Provided	M.R
17.	Standby power supply	Required	Provided 125 KV	M.R
18.	Refuge Area			
	➤ Total Area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire Control Room			
	➤ Detector System Panel	Required	Provided	M.R
	➤ Flow Switch Panel	Required	Provided	M.R
	➤ PA system Panel	Required	Provided	M.R
	➤ Batter backup	Required	Provided	M.R
	➤ Building Floor plans	Required	Provided	M.R
20.	Special Fire Protection Systems for Protection of special Risks, if any:	NR	NR	NR

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC vide letter No. **F6/DFS/MS/Cinema/2016/1775 dated 08/12/16** renewal under rule 35 of the Delhi Fire Service rule 2010 is recommended.

**Note :- The decorative cloths has used in Audies & passages and certificate for the given by the Shakti Fabrics is placed opposite.**

Signature of the Inspection Officer

Signature of the Inspection Officer

Name Udai Vir Singh

Name

Designation ADO (WP)

Designation

*150/10*  
*Udai Vir Singh*

*D. 16/12/19*

*Cfo - on call*  
*Director*  
*5/12/19*

*ADO WP - 42*

*C.F. 16/12/19 is put up for signature please.*