

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6 DFS/MS/School/2019/SZ/ 2264

Dated: 5/12/19

FIRE SAFETY CERTIFICATE

Certified that the SDMC Co-Ed Primary School located at Sector-8, RK Puram, New Delhi-110022 comprised of ground plus one upper floor only, having total 07 class rooms, 01 office and 01 pota cabin owned/occupied by the SDMC was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/SZ/2016/1209 dated 25/11/2016. The premise was re-inspected by the officer concerned of this department on 30/11/2019 in presence of Mrs. Harsh Bala (Principal) and found to have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular no. F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class "Educational Building" Group-B, as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 5/12/19 at New Delhi by


(Rajesh Panwar)
Dy. Chief Fire Officer
Tel. 011-26189168


Copy to: -

1. The Principal, SDMC Co-Ed Primary School, Sector-8, R.K. Puram, New Delhi-110022
2. The Dy. Director of Education (South), Directorate of Education (District South), Govt. of NCT of Delhi, Sector-3, R.K. Puram, New Delhi-110022

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

