

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/2019/NDZI/ 2507

Dated: 12/12/19

FIRE SAFETY CERTIFICATE

Certified that the Shree Laxmi Narayan Sewa Ashram Trust (Regd.) Mandawali Fazalpur (Near Balco Society Mkt.) Delhi-92, owned/occupied by Shree Laxmi Narayan Sewa Ashram Trust Comprised of Basement, ground plus two upper floors was issued FSC for ground plus first floor vide letter no. F6/DFS/MS/2016/1467 Dated 03/10/2016. The building have deemed complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 09/10/19 & 11/11/19 in the presence of Mr. R.S. Negi (Manager) of the Community Hall and that the building is fit for occupancy class "D" 'Assembly Building' at G.F & F.F with effect from 12/12/19. For a period of **three** years, subject of conditions printed overleaf.

Issued on 12/12/19 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

To,
Manager,
Shree Laxmi Narayan Sewa Ashram Trust (Regd.),
Mandawali Fazalpur (Near Balco Society Mkt.) Delhi..

Copy to:-

1. The Deputy Health Officer (EDMC),
SHD (N)-Zone, Health Department,
Delhi-110032

109
INSPECTION REPORT

1. Name & address of the building : Shree Laxmi Narayan Sewa Ashram Trust (Regd.)
Mandawali Fazalpur (Near Balco Society Mkt.) Delhi.
2. Building is comprised of : B+G+2 Upper floors
3. Type of Occupancy : Assembly (Banquet Hall) *at G.F+FF. (15)*
4. Type of Case : New Case
5. Details of Previous NOC : F6/DFS/MS/2016/1467 dated 03/10/2016
6. Fire Safety direction letter No : F6/DFS/MS/BP/2004/72 Dated-12/01/04
7. Date of Inspection : 09/10/19 & 11/11/19
8. Name of the Inspecting Officers: : R.K.Yadav (ADO)
9. Name of the designation of Officer
from the building side : R.S.Negi (Manager)
10. Year of Construction : 2004
11. Applicant's letter No : Nil dated 06/09/19

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement /NBC	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	18 m	MR
	Gate width	4.5 m	4.5 m	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2 no.	2 no.	MR
	Basement	2 no.	2 no.	MR
	b. Width of Staircases			
	Upper Floor	1.5 m	1.5 m each	MR
	Basement	1.5 m	1.5 m each	MR
	c. Protection of exits			
	Fire check door	Required	provided	MR
	Pressurization	Required	provided	MR
	e. No. of continuous staircases to terrace	2 no.	2 no.	MR
	g. Width of Corridor	N.A.	N.A.	N.A.
h. No. of door	2 no.	2 no.	MR	
i. Door Size	2 m	<i>GF</i> 2 m, 1.10m <i>FF</i> & 1.60 m	MR	
3	Compartmentation.			
	Fire check door	Required	provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	Ventilated	provided	MR
	Upper floor	Ventilated	Ventilated	MR
5	Fire Extinguisher			
	Total numbers	10 no.	provided	MR
	types	CO ₂ & ABC	provided	MR
	IS marking	ISI marked	provided	MR

