

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110001**

No. F.6/DFS/MS/Indl./2019/SZ/ 2270

Dated: 06/12/19

**FIRE SAFETY CERTIFICATE**

Certified that **M/s Supreme Metal Craft Medical Products (P) Ltd.** Plot No. G-9, Block B-1, MCIE, Mathura Road New Delhi-110044, comprised of basement, ground plus two upper floors owned/occupied by M/s Supreme Metal Craft Medical Products(P) Ltd. was granted NOC by this department vide letter No. F6/DFS/MS/Indl./2015/SZ/1341 Dated 23/07/2015. The premises was re-inspected by officer concerned of this department on 21/11/2019 in the presence of Sh. Sagar Gupta and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules Act-2007 & Rules- 2010 and that premises/building is fit for occupancy class "Industrial" effect from 06/12/19 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 06/12/19 at New Delhi by

  
(Atul Garg)  
Director  
Delhi Fire Service  
#2 o/c

Copy to: -

1. The Authorized Signatory, M/s Supreme Metal Craft Medical Products (P) Ltd. Plot No. G-9, Block B-1, MCIE, Mathura Road New Delhi-110044
2. The executive Engineer (Bldg.)-I, SDMC, 8<sup>th</sup> floor, Civic Centre, Minto Road, New Delhi-110002.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



# INSPECTION REPORT

1	Name & Address of the Building	M/s Supreme Metal Craft Medical Products (P) Ltd. Plot No. G-9, Block B-1, MCIE, Mathura Road New Delhi-110044		
2	Type of Occupancy	Group-G (Industrial)		
3	Building Comprised of	Basement + Ground + 02 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Ind./2015/SZ/1341 dated 23/07/2015		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2008/574 DATED 28/02/2008		
7	Date of Inspection	21/11/2019		
8	Name of the Inspecting Officers	AVTAR SINGH, ADO (MR)		
9	Name & Designation of Officers from the building side	Mr. Sagar Gupta		
10	Year of construction	2006-07		
11	Applicant letter No.	Outdoor diary no. 22000 dated 04/10/2019		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/NBC Requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	➤ Road width	9 m	Provided	MR
	➤ Gate width	4.5 m	4.5m	MR
	➤ Width of internal road	06m	Provided	MR
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	Two	Provided	MR
	➤ Basement floor.	Two	Provided	MR
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.5m each	Provided	MR
	➤ Basement floor	1.5m each	Provided	MR
	<b>c) Protection of exits</b>			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	01	01	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	-NA-	-NA-	-NA-
3	<b>Compartmentation.</b>			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	Provided	MR
	• Upper floors	12 ACPH	Provided	MR
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	16 Nos	Provided	MR
	• Types	ABC /Co2	ABC /Co2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	<b>First Aid Hose Reels.</b>			



	• Nozzle Diameter	5mm	provided	MR
7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	Smoke	provided	MR
	• Location of Main Panel	ground floor	provided	MR
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	Required	provided	MR
	• Hooter's location	Required	Provided at each floor	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	-NA-	-NA-	-NA-
10.	<b>Automatic Sprinkler System</b>			
	• Basement.	Required	Provided	MR
	• Ground & Above floors	Required	Provided	MR
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>			
	• Size of Riser / Down-comer	150mm	Provided	MR
	• Number of Hydrant per floor	One	Provided	MR
	• Hose box.	One	Provided	MR
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	One	Provided	MR
	• Hose box	One	Provided	MR
13.	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	2280 LPM	Provided	MR
	➤ Head of main pump.	48m	Provided	MR
	➤ Number of main pumps.	One	Two	MR
	➤ Jockey Pump output.	180LPM	Provided	MR
	➤ Jockey Pump head.	48m	Provided	MR
	➤ Standby Pump output.	2280LPM	Provided	MR
	➤ Standby Pump head.	48m	Provided	MR
	➤ Auto Starting/Manual Stopping.	Required	Provided	MR
	➤ Pump house access	Required	Provided	MR
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	900LPM	Provided	MR
	➤ Head of pump.	35m	Provided	MR
	➤ Power supply.	Required	Provided (DG Set)	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	<b>Captive water storage for firefighting.</b>			
	• Underground tank capacity.	1,00,000 Ltrs	Provided	MR
	➤ Draw-off connection.	Required	Provided	MR
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	20,000 ltrs	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	Required	Provided	MR
	• Fireman's switch.	Required	Provided	MR

- N/23 -

	• Lift signage.	Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	• Detector System Panel.	Required	Provided	MR
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	02 ABC type fire extinguisher found provided near electric panel	MR

The fire protection system provided in the building were test checked and found functional at the time of inspection.

In view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to grant Fire Safety Certificate under the Delhi Fire Service Act-2007 & Rule- 2010.

DFA is put up for approval & signature please.

*[Signature]*  
28/11/19

Signature of the Inspecting Officer

Name : Avtar Singh

Designation: ADO (M.RD)

DO (SD)

*[Signature]*  
29/11

*[Signature]*  
29/11

*[Signature]*  
29/11

*[Signature]*  
29/11/19  
#5 D



all cases please