


GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2019 / 2292

Dated: 10 / 12 / 2019

FIRE SAFETY CERTIFICATE

Certified that the **Tomar Public School** located at **Village- Bhorgarh, Delhi-110040** comprised of **Ground + 02 upper floors** owned/ occupied by **Tomar Public School** was issued Fire Safety Certificate vide this office letter no. **F-6/MS/DFS/2006/3454 dated 28.11.2006 (G+01 floor)**. The premise was re-inspected by the officer concerned of this department on **21.11.2019** in the presence of **Sh.Vinod Kumar Tomar, Manager** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premises have deemed complied with requirements of circular issued by **Director of Education letter no F.16/Estate/CC/Fire Safety/2011/3298-3798 dated 01.03.2011** and the building/ premise is fit for occupancy "**Group B Educational**" for **ground and 02 upper floors** with effect from **10/12/19**... for a period of three years, in accordance with rule 36 unless under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010:


(Arul Garg)
Director

Ph:- 011-23414000

Copy to :-

- 1 The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal Tomar Public School , Village- Bhorgarh, Delhi-110040.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

- 1 Name & address of the building :Tomar Public School, Village- Bhorgarh, Delhi-110040.
- 2 Type of Occupancy :Educational
- 3 Type of Case :Renewal/Add./Alt. (Ground + 02 upper floor)
- 4 Details of previous NOC :No.F.6/MS/DFS/2006/3454 dated 28.11.2006(G+01 floor)
- 5 Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
- 6 Date of inspection : 21.11.2019
- 7 Name of the Inspecting Officers : ADO (RN)
- 8 Name and designation of officers
from the building side : Mr. Vinod Kumar Tomar (Manager)
9. Year of Construction : 2005/ 2011
10. Applicant's letter No. : T/P/S dated 30.10.2019

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.25m & 95cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	1m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA

