

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2019 / **2292**

Dated: **10 / 12 / 2019**

FIRE SAFETY CERTIFICATE

Certified that the **Tomar Public School** located at **Village- Bhorgarh, Delhi-110040** comprised of **Ground + 02 upper floors** owned/ occupied by **Tomar Public School** was issued Fire Safety Certificate vide this office letter no. **F-6/MS/DFS/2006/3454 dated 28.11.2006 (G+01 floor)**. The premise was re-inspected by the officer concerned of this department on **21.11.2019** in the presence of **Sh.Vinod Kumar Tomar, Manager** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premises have deemed complied with requirements of circular issued by **Director of Education letter no F.16/Estate/CC/Fire Safety/2011/3298-3798 dated 01.03.2011** and the building/ premise is fit for occupancy "**Group B Educational**" for **ground and 02 upper floors** with effect from **10/12/19** for a period of three years, in accordance with rule 36 unless under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010:


(Arul Garg)
Director

Ph:- 011-23414000

Copy to :-

- 1 The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal Tomar Public School , Village- Bhorgarh, Delhi-110040.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://delhi.gov.in/wps/wcm/connect/doit fire/FIRE/Home/Forms](http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms).
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

- 1 Name & address of the building :Tomar Public School, Village- Bhorgarh, Delhi-110040.
- 2 Type of Occupancy :Educational
- 3 Type of Case :Renewal/Add./Alt. (Ground + 02 upper floor)
- 4 Details of previous NOC :No.F.6/MS/DFS/2006/3454 dated 28.11.2006(G+01 floor)
- 5 Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
- 6 Date of inspection : 21.11.2019
- 7 Name of the Inspecting Officers : ADO (RN)
- 8 Name and designation of officers
from the building side : Mr. Vinod Kumar Tomar (Manager)
9. Year of Construction : 2005/ 2011
10. Applicant's letter No. : T/P/S dated 30.10.2019

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.25m & 95cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	1 m	1m	MR
	f. Door Size			
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA

	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	5 nos	08 nos	MR
	• Types	ABC/Co2	ABC-08	MR
	• ISI marking	ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450lpm	450 lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 ltrs	10,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			

	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. 994 dated 26.05.2011.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. 3454 dated 28.11.2006(G+01 floor).

Signature of the Inspecting Officer
Name :- Rajesh Kumar
Designation:- ADO/RN

[Handwritten signature]

[Handwritten signature]
26/11/19

[Handwritten signature]
26/11/19

[Handwritten signature]
26/11/19

CFO - com C/L

[Handwritten signature]
26/11/19

KF PL/

[Handwritten signature]

As approved, P.T. letter is
attached for your signature &

[Handwritten signature]
26/11/19

[Handwritten signature]