

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


No. F.6/DFS/MS/Indl./2019/SZ/ 2269

Dated: 06/12/19

FIRE SAFETY CERTIFICATE

Certified that **M/s Mukund Lal Om Prakash & Co.**, located at Plot no.J-4, Block B-1, MCIE, Mathura Road New Delhi-110044, comprised of ground plus two upper floors owned/occupied by M/s Mukund Lal Om Prakash & Co Was granted NOC by this department vide letter No. F6/DFS/MS/Indl./2015/SZ/1358 Dated 29/07/2015. The premise was re-inspected by officer concerned of this department on 21/11/2019 in the presence of Sh. Retd. Col. Dhirender and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules Act-2007 & Rules- 2010 and that premises/building is fit for occupancy class "Industrial" effect from 06/12/19. for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 06/12/19 at New Delhi by


(Atul Garg)
Director
Delhi Fire Service
H2 o/c

Copy to: -

1. The Authorized Signatory, M/s Mukund Lal Om Prakash & Co., located at Plot no.J-4, Block B-1, MCIE, Mathura Road New Delhi-110044
2. The executive Engineer (Bldg.)-I, SDMC, 8th floor, Civic Centre, Minto Road, New Delhi-110002.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	Mukund Lal Om Prakash & Co., J-4, Block B-1, MCIE, Mathura Road New Delhi-110044		
2	Type of Occupancy	Group-G (Industrial)		
3	Building Comprised of	Ground + 02 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Ind./2015/SZ/1358 dated 29/07/2015		
6	Fire Safety Directives Letter No	F6/MS/DFS/BP/2003/181 dated 22/01/2003 & F6/DFS/MS/BP/2008/08 DATED 02/01/2008		
7	Date of Inspection	21/11/2019		
8	Name of the Inspecting Officers	AVTAR SINGH, ADO (MRd)		
9	Name & Designation of Officers from the building side	Retd. Col. Dhirender (Site Leader)		
10	Year of construction	2008-09		
11	Applicant letter No.	Outdoor diary no. 21999 dated 04/10/2019		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	➤ Road width	9 m	Provided	MR
	➤ Gate width	5 m	4.5m	MR(old case)
	➤ Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Two + One Spiral	Provided	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.25m	1.43m, 1.2m + 0.7m	MR(old case)
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Two	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1m	Provided (final exit)	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	12 ACPH	Exhaust	MR
5.	Fire Extinguishers.			
	• Total numbers	30 Nos	30	MR
	• Types	ABC / W.Co2/Co2	10/10/10	MR
	• ISI Marking	ISI marked	Provided	MR

	<ul style="list-style-type: none"> Total numbers on each floor 	Two	provided	MR
	<ul style="list-style-type: none"> Length of hose-reel hose. 	36m	provided	MR
	<ul style="list-style-type: none"> Nozzle Diameter 	5mm	provided	MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Smoke & heat ground floor	provided	MR
		-NA-	provided	MR
		Required	-NA-	-NA-
		All area	provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-N/A-	-N/A-	-N/A-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Ground & Above floors 	-N/A-	Provided	-N/A-
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-N/A-	-N/A-	-N/A-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer 	100mm	Provided	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	Two	Provided	MR
	<ul style="list-style-type: none"> Hose box. 	Two	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	12 no's	Provided	MR
	<ul style="list-style-type: none"> Hose box 	12 no's	Provided	MR
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	1620 LPM	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of main pump. 	60m	Provided	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	One	Two	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	180LPM	Provided	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	60m	Provided	MR
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	1620LPM	Provided	MR
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	60m	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping. 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Pump house access 	Required	Provided	MR
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	450LPM	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of pump. 	40m	Provided	MR
	<ul style="list-style-type: none"> ➤ Power supply. 	Provided	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	Provided	Provided	MR
14.	Captive water storage for firefighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	50,000 Ltrs	1,00,000 Ltrs	MR
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Access to tank. 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead tank capacity. 	5,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Communication in lift car 			

- N/13 -

	• Fireman's switch.	-N/A-	Provided	-N/A-
	• Lift signage.	-N/A-	Provided	-N/A-
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	-N/A-	-N/A-	-N/A-
	• Location	-N/A-	-N/A-	-N/A-
19.	Fire Control Room.			
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	-N/A-	-N/A-	-N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	ABC extinguisher provided near electric panel	MR

The fire protection system provide in the building were tested checked and found functional at the time of inspection

In view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to grant Fire Safety Certificate under the Delhi Fire Service Act-2007 & Rule- 2010.

DFA is put up approval & signature please.

(Signature)
28/11/19

Signature of the Inspecting Officer

Name : Avtar Singh

Designation : ADO (M.R)

DO (SD)

(Signature)
29/11

(Signature)
DCFD(SZ)

(Signature)
29/11

(Signature)
29/11/19
29/11/19

(Signature)
Adu/MR

as per the requirement please

