

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2020/SZ/ 08

Dated: 06/01/2020

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name & style of M/s **Diablo** (A Unit of First Fiddle F&B, Pvt. Ltd) situated at D1, Block-D, H-5/12, Kalka Das Marg, Mehrauli, New Delhi-110030, comprised of Ground Floor only have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on 30/12/2019 in the presence of Sh. Sanjay Pandey and that the premises is fit for occupancy class "**Group-D Assembly**" with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06/01/2020 at New Delhi by

(Atul Garg)
Director

Tel. 011-23414000

Copy to: -

1. The Dy. Health Officer, South Delhi Municipal Corporation, South Zone, Aurobindo Marg, Green Park, New Delhi-110016 [w.r.t. letter no. DHO/SZ/2019/D 1515 dated 04/11/19]
2. The Joint Commissioner of Police (Lic.), First Floor, Police Station Defence Colony, New Delhi-110049
3. Shri Gaurav Gupta, Director M/s **Diablo** (A Unit of First Fiddle F&B, Pvt. Ltd) situated at D1, Block-D, H-5/12, Kalka Das Marg, Mehrauli, New Delhi-110030

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT				
1	Name & Address of the Building	M/s DIABLO (A unit of First Fiddle F&B Pvt. Ltd) in commercial area at D1, Blk-D, H-5/12 First floor, Kalka Das Marg, Mehrauli, New Delhi-110030		
2	Type of Occupancy	Group-D, "Assembly"		
3	Building Comprised of	Ground Floor only		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	30-12-2019		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. Sanjay Pandey (Liaison Officer)		
10	Year of Construction/Conversion	2013 / 2014		
11	Applicant letter No.	Outdoor Diary No. 26441 dated 29-11-2019		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/NBC-2005 Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	6m N/A N/A	Provided Abut on Road N/A	MR N/A N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	<ul style="list-style-type: none"> Upper floors. Basement floor. 	N/A N/A	N/A N/A	N/A N/A
	b) Width of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	N/A N/A	N/A N/A	N/A N/A
	c) Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d) No. of continuous staircase to terrace	N/A	Provided	N/A
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	2m & 1m	2m each	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	Required N/A N/A N/A N/A	Provided N/A N/A N/A N/A	MR N/A N/A N/A N/A
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Ground floor 	30 ACPH 12 ACPH	N/A Provided	N/A MR
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	Required ABC/CO2/W. CO ₂ Required	6 Nos ABC & CO ₂ Provided	MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	One 30m 5mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	N/A N/A N/A N/A N/A	Smoke Detector Ground Floor N/A Provided Near Entry/Exit	N/A N/A N/A N/A N/A

N/4

M/s Diablo (U/o First Fiddle F&B Pvt. Ltd) at D1, Blk-D, H-5/12, Kalka Das Marg, Mehrauli, New Delhi

Covered Area of the Establishment: 354 sq.mtr / 1.8 = 196.66 or 197 Persons

The Fire protection systems provided in the building/premises were test checked at random and found functional at the time of inspection. Keeping in view of the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules, 2010.

Accordingly, DFA is put up for approval and signature please.

[Handwritten Signature]
21/11

Signature of the Inspecting Officer
Name: Mehmood
Design: ADO (SJ)

DO (SD)

[Handwritten Signature]
02/11/2020

By cfo (S2) on D/O

cfo (S2) on leave

Director *[Handwritten Signature]*
3/11/2020

FT PS

AD(SJ)

Sd.

A D.T Delhi puray jar *[Handwritten Signature]* please

Director *[Handwritten Signature]*
6/11/2020

[Handwritten Signature]
6/11/2020
AD(SJ)

[Handwritten Signature]

8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Ground Floor. 	N/A	Provided	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	One	Provided	MR
	<ul style="list-style-type: none"> Hose box. 	One	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose box. 	N/A	N/A	N/A
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of main pump. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump house access. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	450 LPM	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of pump. 	40m	Provided	MR
	<ul style="list-style-type: none"> ➤ Power supply. 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	Required	Provided	MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead tank capacity. 	10,000 Ltr	20,000 Ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication in lift car. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fireman's switch. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift signage. 	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location 	N/A	N/A	N/A
19	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Flow switch panel. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> PA system panel. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Battery backup. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Building floor plan. 	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A