

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001


No.F6/DFS/MS/School/2019/NDZ/ 2356

Dated: 20/12/19

**FIRE SAFETY CERTIFICATE**

Certified that the EDMC Pratibha School at block-19, Kalyanpuri, Delhi-91, comprising of ground plus one floor owned/occupied by EDMC Pratibha School FSC was issued vide letter no. F6/DFS/MS/School/2016/NDZ/376 Dated 09/03/16. The School building have complied with the fire prevention and fire safety requirements in accordance with the circular no.F.16/Estate/CC/FS/2011/3298 to 3398 dated 01/03/11 issued by the Director of Education and verified by the officer concerned of this department on 04/12/19 in the presence of Sh. Ram Chand (Principal) of the school and found that the building is fit for occupancy class B 'Educational Building' for with effect from ...20/12/19... for a period of **three** years, subject to conditions printed overleaf.

Issued on.....20/12/19.....at New Delhi by

  
(Sunil Chawdhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

To,

The Principal,  
EDMC Pratibha School at block-19,  
Kalyanpuri, Delhi-91

Copy to:-

The Director of Education,  
East Delhi Municipal Corporation,  
419, Udyog Sadan, Patparganj Industrial Area, Delhi-92.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept unlocked & free from any obstruction.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate cannot be treated in any case for regularizations of unauthorized construction or Alteration if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

1. Name & address of the building : EDMC Pratibha School at block-19, kalyanpuri, Delhi-91.
2. Building is comprised of : G+1
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/School/2016/NDZ/376 Dated 09/03/16
6. Fire Safety Circular No. : F.16/Estate/CC/FS/2011/3298 to 3398 dt-1.3.11
7. Date of Inspection : 04/12/19
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of Officer from the building side : Sh. Ram Chand (Principal )
10. Year of Construction : 2011
11. Applicant's letter No : Nil Dated 21/11/19

| N o. | Minimum Standards on fire prevention and fire safety U/R33 | Circular Requirement | Provided at Site | Remarks |
|------|--|----------------------|------------------|---------|
| 1    | Access to building   |                      |                  |         |
|      | • Road width   | 06 M                 | 06 M             | MR      |
|      | • Gate width   | N/A                  | N/A              | N/A     |
|      | • Width of internal road                                   | N/A                  | N/A              | N/A     |
| 2    | Number, Width, Type and Arrangement of Exits               |                      |                  |         |
|      | a. Number of Staircases                                    |                      |                  |         |
|      | • Upper Floor  | 02 Nos.              | 02 Nos.          | MR      |
|      | • Basement   | N/A                  | N/A              | N/A     |
|      | B. Width of Staircases                                     |                      |                  |         |
|      | • Upper Floor  | 1.5 M                | 1.5 M each       | MR      |
|      | • Basement   | N/A                  | N/A              | N/A     |
|      | c. Protection of exits                                     |                      |                  |         |
|      | • Fire check door  | N/A                  | N/A              | N/A     |
|      | • Pressurization   | N/A                  | N/A              | N/A     |
|      | e. No. of continuous staircases to terrace                 | 01 No.               | 01 No.           | MR      |
|      | g. Width of Corridor                                       | 1.5 M                | 1.5 M            | MR      |
|      | h. Door Size   | 1.0 M                | 1.0 M            | MR      |
| 3    | Compartmentation.  |                      |                  |         |
|      | • Fire check door  | N/A                  | N/A              | N/A     |
|      | • Sealing of electrical shafts                             | N/A                  | N/A              | N/A     |
|      | • Fire rating of shaft door                                | N/A                  | N/A              | N/A     |
|      | • Water curtain  | N/A                  | N/A              | N/A     |
|      | • Fire Dampers   | N/A                  | N/A              | N/A     |
| 4    | Smoke Management System.                                   |                      |                  |         |
|      | • Basement   | N/A                  | N/A              | N/A     |
|      | • Upper floor  | N/A                  | N/A              | N/A     |
| 5.   | Fire Extinguishers   |                      |                  |         |
|      | • Total numbers  | 04 Nos.              | 04 Nos.          | MR      |
|      | • types  | ABC & Co2            | ABC & Co2        | MR      |
|      | • IS marking   | ISI marked           | ISI marked       | MR      |

2/11

|    |   |     |     |     |
|----|---|-----|-----|-----|
| 6  | First-aid-Hose Reels.                         |     |     |     |
|    | Total numbers of each floor                   | N/A | N/A | N/A |
|    | • Length of hose reel hose                    | N/A | N/A | N/A |
|    | • Nozzle diameter                             | N/A | N/A | N/A |
| 7  | Automatic fire detection and alarming system. |     |     |     |
|    | • Type of detectors                           | N/A | N/A | N/A |
|    | • Location of main panel                      | N/A | N/A | N/A |
|    | • Location of repeater panel                  | N/A | N/A | N/A |
|    | • Alternate source of power                   | N/A | N/A | N/A |
|    | • Hooter's location                           | N/A | N/A | N/A |
| 8  | MOEFA   | N/A | N/A | N/A |
| 9  | Public address System.                        | N/A | N/A | N/A |
| 10 | Automatic Sprinkler System.                   | N/A | N/A | N/A |
|    | • Basement                                    | N/A | N/A | N/A |
|    | • upper floor                                 | N/A | N/A | N/A |
|    | • sprinkler above false ceiling               | N/A | N/A | N/A |
| 11 | Internal Hydrants                             |     |     |     |
|    | • size of riser/down-comer                    | N/A | N/A | N/A |
|    | • Number of hydrants per floor                | N/A | N/A | N/A |
|    | • Hose Box                                    | N/A | N/A | N/A |
| 12 | Yard Hydrants.                                |     |     |     |
|    | • Total number of hydrants                    | N/A | N/A | N/A |
|    | • Hose Box                                    | N/A | N/A | N/A |
| 13 | Pumping Arrangements.                         |     |     |     |
|    | • Ground Level                                | N/A | N/A | N/A |
|    | ➤ Discharge of main Pump                      | N/A | N/A | N/A |
|    | ➤ Head of Main Pump                           | N/A | N/A | N/A |
|    | ➤ Number of main pumps                        | N/A | N/A | N/A |
|    | ➤ Jockey pump out put                         | N/A | N/A | N/A |
|    | ➤ Jockey pump head                            | N/A | N/A | N/A |
|    | ➤ Standby pump out put                        | N/A | N/A | N/A |
|    | ➤ Standby pump Head                           | N/A | N/A | N/A |
|    | ➤ Auto Starting /Manual stopping              | N/A | N/A | N/A |
|    | ➤ Pump House Access                           | N/A | N/A | N/A |
|    | • Terrace Level                               | N/A | N/A | N/A |
|    | ➤ Discharge of pump                           | N/A | N/A | N/A |
|    | ➤ Head of the Pump                            | N/A | N/A | N/A |
|    | ➤ Power supply                                | N/A | N/A | N/A |
|    | ➤ Auto Starting of pump                       | N/A | N/A | N/A |
| 14 | Captive Water Storage for Fire Fighting.      |     |     |     |
|    | • Underground tank capacity                   | N/A | N/A | N/A |
|    | ➤ Draw-off connection                         | N/A | N/A | N/A |
|    | ➤ Fire service inlet                          | N/A | N/A | N/A |
|    | ➤ Access to tank                              | N/A | N/A | N/A |
|    | • Overhead Tank capacity                      | N/A | N/A | N/A |
| 15 | Exit Signage.                                 | N/A | N/A | N/A |


lm

N/12

|    |  |     |     |     |
|----|--|-----|-----|-----|
| 16 | Provision of Lifts.  |     |     |     |
|    | • Pressurization of Lift Shaft   | N/A | N/A | N/A |
|    | • Pressurization of Lift lobby   | N/A | N/A | N/A |
|    | • Communication in lift car  | N/A | N/A | N/A |
|    | • Firemen's grounding switch   | N/A | N/A | N/A |
|    | • Lift Signage   | N/A | N/A | N/A |
| 17 | Standby power supply   | N/A | N/A | N/A |
| 18 | Refuge Area.   |     |     |     |
|    | • Total area   | N/A | N/A | N/A |
|    | • Location   | N/A | N/A | N/A |
| 19 | Fire Control Room  |     |     |     |
|    | • Detector system panel  | N/A | N/A | N/A |
|    | • Flow switch panel  | N/A | N/A | N/A |
|    | • PA system panel  | N/A | N/A | N/A |
|    | • Battery backup   | N/A | N/A | N/A |
|    | • Building Floor Plans   | N/A | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/checked at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules. The FSC was issued vide letter no F6/DFS/MS/School/2016/NDZ/1376 Dated 09/03/16 renewal under the circular no. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/11 is recommended.

  
 Signature of the Inspecting Officer  
 Name: R. K. Yadav  
 Designation: ADO(LN)

~~DO(ED)~~ submitted for approval plan.

DY. CEO/NDZ/n.

[Signature]  
6/12

[Signature]  
4/12/19.

DO(ED)

[Signature]  
9/12

ADO/LN

FT letter & put up for signature please