

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/Storage/SZ/2020/ 07

Dated: 07/01/2020

FIRE SAFETY CERTIFICATE

Certified that M/s **Express Cargo Terminal of Celebi Delhi Cargo Terminal Management India Pvt. Ltd.**, IGI Airport, New Delhi-110037, comprised of ground and one upper floor was inspected by the officers concerned of this department on 23/11/2019 in the presence of Mr. Rakesh Kumar (Fire Officer) and found that the said building have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class **Group-B (Storage Building)** with effect from 07/01/ 2020 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions mentioned under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/01/2020 at New Delhi by

(Atul Garg)
Director

Tel: 011-23414000

Copy to: -

1. Sh. Murali Ramachandran (CEO - India), M/s Celebi Delhi Cargo Terminal Management India Pvt. Ltd., IGI Airport, New Delhi-110037
2. Sh. Hrishekhran, GM (Fire), New Udaan Bhawan, Terminal-3, IGI Airport, New Delhi-110037

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/occupier shall submit a declaration **every year** in **Form 'K'** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

