

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001


NO. F.6/DFS/MS/EH/2018/ 184

Dated:- 30/1/2018

FIRE SAFETY CERTIFICATE

Certified that the **M/S Shehnai Banquet Hall, Asaf Ali Road, M.L.U.G. car parking**, located at **Asaf Ali Road M.L.U.G. Car Parking, New Delhi 110002**. Comprised of **Ground floor &** occupied by **M/S New Shehnai Banquet Hall** has complied with the fire prevention & fire safety requirements in accordance, with rule 33 of the Delhi Fire Service rules 2010 and verified by the officer concerned of Delhi Fire Service on **11-01-2018** in the presence of **Sh. Harish Kumar Arora** and the building / premises, is fit for occupancy class **Assembly Building Group D** with effect from 30/1/18 for period of **three** years in accordance with Rule 36 unless under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued on 30/1/18 at New Delhi.


(Sunil Chawdhary)
Dy.Chief Fire Officer
Delhi Fire Service

Copy to:- 1. The Medical Officer of Health,
NDMC Palika Kendra New Delhi.
2. The licensee
Sh. Harish Kumar Arora Shehnai Banquet hall
Asf ali Road M.L.U.G. Car Parking New Delhi-110002.

Following fire safety directives may be adhered to :-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. The means of escape shall be kept unobstructed/unlocked & remain available for speedy evacuation of occupants in case of an emergency.
of smooth and speedy safe evacuation of occupants in case of emergency
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regard to construction, electric shall be verified by the concerned building sanctioning authority.
5. The trained fire fighting staff should be available around the clock.
6. This fire safety certificate may not be treated in any case for regularizations of unauthorized construction if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi fire service 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this fire safety certificated to the director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to it expiry.

INSPECTION REPORT

1. Name & address of the building : Shehnai, Banquet Hall, Asaf Ali Road, M.L.U.G. Car Parking,
New Delhi- 110002
2. Building is comprised of : Ground Floor
3. Type of Occupancy : Assembly
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : Nil
7. Date of Inspection : 11-01 -2018.
8. Name of the Inspecting Officers: : Sunil Chawdhary (Dy.CFO NDZ)/ A.D.O Manoj sharma
9. Name of the designation of Officer
from the building side : Sh. Harish Kumar Arora
10. Year of Construction : Nil
11. Applicant's letter No : Nil


S.No	Minimum Standards on fire prevention and fire safety U/R33	Existing fire safety as per NBC/BBL	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 mtr.	12 mtr.	MR
	Gate width	5 mtr.	Provided	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	Nil	Nil	Nil
	Basement	Nil	Nil	Nil
	B. Width of Staircases			
	Upper Floor	Nil	Nil	Nil
	Basement	Nil	Nil	Nil
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	d. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	e. Width of Corridor	N.A.	N.A.	N.A.
f. Door Size	2x2 Mtr.	2x2 mtr. 3x1.75 mtr.	MR	
3	Compartmentation.			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	12a/c per hour	Provided	MR
	Upper floor	12a/c per hour	Provided	MR

5.	Fire Extinguisher			
	Total numbers	15 no.	20 Provided	MR
	Types	ABC & Wco ₂	Provided	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	02 no.	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters's location	N.A.	N.A.	N.A.
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	basement.	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	Required	Provided	MR
	Number of hydrants per floor	2	Provided	MR
	Hose Box	2	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	Ground Level	N.A.	N.A.	N.A.
	Discharge of main Pump	N.A.	N.A.	N.A.
	Head of Main Pump	N.A.	N.A.	N.A.
	Number of main pumps	N.A.	N.A.	N.A.
	Jockey pump out put	N.A.	N.A.	N.A.
	Jockey pump head	N.A.	N.A.	N.A.
	Standby pump out put	N.A.	N.A.	N.A.
	Standby pump Head	N.A.	N.A.	N.A.
	Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	Pump.House Access	N.A.	N.A.	N.A.
	Terrace Level			
	Discharge of pump	450 Lpm	Provided	MR
	Head of the Pump	30 mtrs	Provided	MR
	Power supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	20,000 Liters	Provided	MR
15	Exit Signage.	required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	required	Provided	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were tested , checked and found functional at the time of inspection.

In view of the Deemed compliance of the compliance of the minimum standards of fire prevention and fire safety measures as required under the Rule 35 of the Delhi Fire Service Rule 2010/ recommended for FSC please.



Signature of the Inspecting Officer

Name Sunil Chawdhary

Designation DY. CFO (NDZ)

C.F.O.

M. Scell

FTM.

29/11

F.T. letter is put up for signature