GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001.

No. **F6/DFS/MS/EH/2020/NDZ/** 09 Dated: 6/01/20

FIRE SAFETY CERTIFICATE

Certified that the Burger King India Pvt. Ltd. running at ground plus first floor of building comprised of basement, ground plus three upper floors at F-15, Vijay Block, Laxmi Nagar Delhi-92, owned/occupied by Burger King India Pvt. Ltd was issued FSC vide letter no.F6/DFS/MS/2016/NDZ/1221 Dated 29/11/16.The premises was inspected by the officer concerned of this department on 22/12/19 in the presence of Manager of the restaurant and found that the building have deemed complied with the fire prevention and fire safety requirement in accordance with the BBL & NBC Part-IV and that the ground plus one upper floor of building is fit for occupancy class 'Eating House' (Restaurant) for with effect from ..6/1/2020. for a period of **three** years, subject to conditions printed overleaf.

Issued on.....06/01/2020.....at New Delhi by

(Sunil Chawdhary)
Dy.Chief Fire Officer

To,

The Manager,
Burger King India Pvt. Ltd.,
F-15,Vijay Block, Laxmi Nagar Delhi-92

Copy:-

The Deputy Health Officer,
Shahdara (South) Zone, EDMC,
Health Department, Shahdara South Zone, Karkardooma, Delhi

Conditions

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6 This FSC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any
7 The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"
8 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : Burger King India Pvt, Ltd,F-15,Vijay block, Laxmi Nagar,Delhi-92.
2. Building is comprised of : basement, ground plus three upper floors (Restaurant at ground & first floor only)
3. Type of Occupancy : Assembly
4. Type of Case : Renewal
5. Details of Previous FSC : F6/DFS/MS/2016/NDZ/1221 Dated 29/11/16
6. Fire Safety direction letter No : BBL & NBC Part-IV
7. Date of Inspection : 22/12/2019
8. Name of the Inspecting Officers: : R.K.Yadav ADO(LN)
9. Name of the designation of Officer from the building side : Manager
10. Year of Construction : 1980
11. Applicant's letter No : Nil Dated 09/12/2019

s.no	Minimum Standards on fire prevention and fire safety U/R33	BBL & NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	06 m	24 m	MR
	Gate width	NA	NA	NA
	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	1 no.	2 no.	MR
	Basement	1 no.	2 no.	MR
	b. Width of Staircases			
	Upper Floor	1.5 m	1.5 m & 1 m	MR
	Basement	1.5 m	1.5 m & 1 m	MR
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	1 no.	1 no.	MR
	g. Width of Corridor	NA	NA	NA
	h. Door Size	2 m	2 m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	Required	Ventilated	MR
	• Upper floor	Required	Ventilated	MR
5.	Fire Extinguisher			
	• Total numbers	10 no.	10 no.	MR
	• Types	CO_2 + ABC	CO_2 + ABC	MR
	• IS marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	01 no	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Heat	Provided	MR
	Location of main panel	NA	NA	NA
	Location of repeater panel	NA	NA	NA
	Alternate source of power	NA	Provided	MR
	Hooter's location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	basement	NA	NA	NA
	upper floor	Required	Provided	MR
	sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	size of riser/down-comer	NA	100 mm	MR
	Number of hydrants per floor	NA	1 no	MR
	Hose Box	NA	1 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level	NA	NA	NA
	➢ Discharge of main Pump	NA	NA	NA
	➢ Head of Main Pump	NA	NA	NA
	➢ Number of main pumps	NA	NA	NA
	➢ Jockey pump out put	NA	NA	NA
	➢ Jockey pump head	NA	NA	NA
	➢ Standby pump out put	NA	NA	NA
	➢ Standby pump Head	NA	NA	NA
	➢ Auto Starting /Manual stopping	NA	NA	NA
	➢ Pump House Access			
	• Terrace Level			
	➢ Discharge of pump	450 LPM	450 LPM	MR
	➢ Head of the Pump	40 M	40 M	MR
	➢ Power supply	Required	Provided	MR
	➢ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	10,000 Ltrs	10,000 Ltrs	MR
15	Exit Signage.	Required	Provided	MR

N/2

16	Provision of Lifts.			
	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	N/A	N/A	N/A
	Communication in lift car	N/A	N/A	N/A
	Firemen's grounding switch	N/A	N/A	N/A
	Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room			
	Detector system panel	NA	NA	NA
	Flow switch panel	N/A	NA	NA
	PA system panel	N/A	NA	NA
	Batter backup	N/A	NA	NA
	Building Floor Plans	N/A	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection provided in the building were tested/ checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the BBL & NBC Part-IV it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

2/11/2020

Signature of the Inspecting Officer
Name:-R.K.Yadav
Designation :-ADO(LN)

DO(ED) on Leave
I/C DFO (ND2)

F.T. please

3/11/2020

ADO(L-II)

F T letter is put up for sign. please.

6/11/2020

DY CFO (ND2)