

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**

No.F6/DFS/MS/EH/2020/ 14

Dated: 13/01/2020

**FIRE SAFETY CERTIFICATE**

Certified that the M/s DRS Club (Delhi Recreation Society Regd.) located at A-6, First Floor, Subham Enclave, Paschim Vihar, Delhi running on 1<sup>st</sup> Floor only in a building comprised of Basement, Ground Floor, First Floor, Second Floor & Third Floor only owned / occupied by Delhi Recreation Society Regd., have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 06/01/2020 in the presence of Mr. Sanjay and found that the building / premises is fit for the occupancy class "Assembly" (Eating House) **For First Floor Only** with effect from 13/01/2020. for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..... at New Delhi by.

**Issued on** 13/01/2020 **at New Delhi by.**

(ATUL GARG)  
DIRECTOR.

Copy to :-

1. Mr. Praveen Grewal (President), M/s DRS Club (Delhi Recreation Society Regd.), A-6, First Floor, Subham Enclave, Paschim Vihar, Delhi.
2. Dy. Health Officer, NDMC, Rohini Zone, Sec.-5, Rohini, Delhi-110085.
3. Joint Commissioner of Police, Lic.Unit, 1<sup>st</sup> Floor, Police Station Defence Colony, New Delhi.

**Conditions for the validity of Fire Safety Certificate:**

1. The FSC is valid for First Floor only.
2. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)



# INSPECTION REPORT

To see the compliance of office letter no. F6/DFS/MS/2019/WZ/EH/7914 dated 27/12/2019

Total covered area of the restaurant at the ground floor is 187m<sup>2</sup> and as per NBC (Part-IV) the no. of occupants comes out to be Approx. 104 (187/1.8=103.88). Thus capacity of restaurant is 104 persons which is covered under DFS Act 2007, Rules 2010. Subsequently inspection of Eating House is carried out as per NBC (Part-IV).

1. Name & address of the building: **M/s DRS Club (Delhi Recreation Society Regd.)**  
**A-6, F.F., Subham Enclave, Paschim Vihar, Delhi.**

2. Type of Occupancy : **Assembly (E/H)**

3. Type of Case : **New**

4. Details of previous NOC : **Nil**

5. Fire Safety directives Letter No. : **NBC (Part-IV)**

6. Date of inspection : **06/01/2020**

7. Name of the Inspecting Officer : **A.D.O. (Jwp)**

8. Name and designation of Officer  
from the building side : **Sh. Sanjay**

9. Year of Construction : **2013 (As per C/13)**

10. Applicant's letter No. : **online ID No. 2019121000850 dated 16/12/2019**  
**& outdoor diary No. 28174 dated 23/12/2019**

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	On Main Road	MR
	• Gate width	On Main Road	On Main Road	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	2.00 mtr & 1.25mtr	2.00 (Iron) & 1.25 (Concrete)	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	2.00 mtr x 1, 1.25 mtr x 1	2.00 Mtr. x 1, 1.25 Mtr. x 1	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	2	4	M/R
	• Types	ISI marked ABC/CO <sub>2</sub>	Provided	M/R
	• IS marking	Required	Provided	M/R



6.	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke	Smoke	MR
	• Location of Main Panel	1 <sup>ST</sup> Floor	1 <sup>ST</sup> Floor	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Ground Floor	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	150 mm	MR
	• Number of hydrants per floor	1	1	MR
	• Hose Box	1	1	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40 MTR	40 MTR	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A

15	Exit Signage	N/A	N/A	N/A
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

**Note:-A.) Building comprised of Basement (Gym belongs to other party), Ground Floor (Office, other party), First Floor (Proposed Eating House), Second Floor & Third Floor (Vacant).**

**B.) Note- Shortcomings issued by this Department vide Letter No.F6/DFS/MS /2019/WZ/EH/7914 dated 27/12/2019 have been complied.**

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

DO/(WD)

*[Signature]* 8/1/2020

*[Signature]* 8/1/2020

Chd- CH

Director,

9/1/2020

FIP }

*[Signature]* 7/1/2020  
Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : A.D.O. (Jwala Puri)

Kind Sign