

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2020/SZ/11

Dated: 07/01/20

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name & style of M/s **J.R.G. Hospitality Pvt. Ltd**, (Guppi by Ai) situated at Shop No. 28, Main Market, Lodhi Road, New Delhi-110003, comprised of Ground Floor & First Floor only but the restaurant running at ground floor only have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on 05/12/2019 in the presence of Sh. Gaurav Grover (owner) and that the premises is fit for occupancy class "**Group-D Assembly**" with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/01/20 at New Delhi by

(Atul Garg)
Director

Delhi Fire Service
Tel. 011-23414000

Copy to: -

1. Sh. Santosh Kumar Sinha (J.D./Health License), NDMC, Health Licensing Department, Palika Kendra, New Delhi. (W.r.t. letter no. D/429/JD (HL)/S.O. (HL) dated 25/11/2019)
2. Sh. Gaurav Grover M/s **J.R.G. Hospitality Pvt. Ltd**, (Guppi by Ai) situated at Shop No. 28, Main Market, Lodhi Road, New Delhi-110030

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building.	M/s J.R.G Hospitality Pvt. Ltd. (Guppy by Ai), Shop No. 28, Main Market Lodhi Colony, New Delhi-03		
2	Type of Occupancy	Group-D, "Assembly"		
3	Building Comprised of	Ground + First floor. (Restaurant at Gr. Floor & residence at 1 st Floor)		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	05-12-2019		
8	Name of the Inspecting Officers	S K Dua, DO (SD)		
9	Name & Designation of Officers from the building side	Sh. Gaurav Grover (owner)		
10	Year of construction	Prior to 1980 (Property Tax papers in r/o Restaurant, placed on file)		
11	Applicant letter No.	Outdoor Diary No. 25112 dated 26/11/2019		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL 1967 Requirements/ Circular 2011	Provided at Site (Old Restaurant)	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width 	6m	Provided	MR
	<ul style="list-style-type: none"> Gate width 	N/A	On main road	N/A
	<ul style="list-style-type: none"> Width of internal road 	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	N/A	N/A	N/A
	➤ Basement floor.	N/A	N/A	N/A
	b) Width of Staircase			
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	N/A	N/A	N/A
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	Required	1.5 & 1.0 m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sealing of electrical shafts. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire rating of shaft door. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Water curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire dampers. 	N/A	N/A	N/A
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Ground floor 	12 ACPH	Provided	MR
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers 	04 Nos	05 Nos	MR
	<ul style="list-style-type: none"> Types 	ABC/CO2	ABC & CO2	MR
	<ul style="list-style-type: none"> ISI Marking 	Required	Provided	MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. 	One	Provided	MR
	<ul style="list-style-type: none"> Length of hose-reel hose. 	30m	Provided	MR
	<ul style="list-style-type: none"> Nozzle Diameter 	5mm	Provided	MR
7.	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooter's location 	N/A	N/A	N/A

8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	100 mm	Provided	MR
		One	Provided	MR
		One	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. ➤ Head of main pump. ➤ Number of main pumps. ➤ Jockey Pump output. ➤ Jockey Pump head. ➤ Standby Pump output. ➤ Standby Pump head. ➤ Auto Starting/Manual Stopping. ➤ Pump house access. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump. ➤ Head of pump. ➤ Power supply. ➤ Auto starting of pump. 	450 LPM	450 LPM	MR
		40m	40m	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. Overhead tank capacity. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		5,000 Ltr	10,000 Ltr	MR
15	Exit Signage.	Required	Not Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. Flow switch panel. PA system panel. Battery backup. Building floor plan. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

M/s J.R.G. Hospitality Pvt. Ltd (Guppy by Ai), Shop No. 28, GF, Main Market, Lodhi Road, New Delhi-03

The Fire protection systems provided in the building/premises were test checked at random and found functional at the time of inspection. Keeping in view of the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules, 2010.

Accordingly, DFA is put up for approval and signature please.

[Signature]

Signature of the Inspecting Officer

Name: S K Dua

Designation: DO (SD)

DCFO (SZ)

[Signature]
12/12

[Signature]

what's location of staircase for residence
& if it can effect the residence if
fire occurs on G.F in restaurant area

[Signature]
12/12

[Signature]
16/12

[Signature]
19/12

[Signature]
Sir,

- Entry / Exit are dedicated for the restaurant.
- Staircase is separate from the Entry & Exit Gates.
- It will not effect the residence, if any fire occurs.

