

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2020/SZ/11

Dated: 07/01/20

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name & style of M/s **J.R.G. Hospitality Pvt. Ltd**, (Guppi by Ai) situated at Shop No. 28, Main Market, Lodhi Road, New Delhi-110003, comprised of Ground Floor & First Floor only but the restaurant running at ground floor only have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on 05/12/2019 in the presence of Sh. Gaurav Grover (owner) and that the premises is fit for occupancy class "**Group-D Assembly**" with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/01/20 at New Delhi by

(Atul Garg)
Director

Delhi Fire Service
Tel. 011-23414000

Copy to: -

1. Sh. Santosh Kumar Sinha (J.D./Health License), NDMC, Health Licensing Department, Palika Kendra, New Delhi. (W.r.t. letter no. D/429/JD (HL)/S.O. (HL) dated 25/11/2019)
2. Sh. Gaurav Grover M/s **J.R.G. Hospitality Pvt. Ltd**, (Guppi by Ai) situated at Shop No. 28, Main Market, Lodhi Road, New Delhi-110030

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

