

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**

No.F6/DFS/MS/EH/2020/ W2/13

Dated: 10/01/2020

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Jubilant Food Works Ltd. located at Shop No.-2 & 3, Under via duct Kirti Nagar Metro Station, New Delhi-110015 comprised of Ground Floor only owned / occupied by M/s Jubilant Food Works Ltd., have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 16/11/2019 in the presence of Mr. Shamdev (Manager) and found that the building / premises is fit for the occupancy class "Assembly" (Eating House) with effect from 10.01.2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

**Issued on 10/01/2020 at New Delhi by.**

  
(ATUL GARG)  
DIRECTOR.

 o/c

Copy to :-

1. Addl. Commissioner of Police, Lic.Unit, 1<sup>st</sup> Floor, Police Station Defence Colony, New Delhi .
2. Sh. Naveen Gupta, M/s Jubilant Food Works Ltd., Shop No.-2 & 3, Under via duct Kirti Nagar Metro Station, New Delhi-110015.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

## INSPECTION REPORT

Total covered area of the restaurant at the ground floor is 104m<sup>2</sup> and as per NBC (Part-IV) the no. of occupants comes out to be Approx. 58 (104/1.8=57.77). Thus capacity of restaurant is 58 persons which is covered under DFS Act 2007, Rules 2010. Subsequently inspection of Eating House is carried out as per NBC (Part-IV).

1. Name & address of the building: **M/s Jubilant Food Works Ltd., Shop No.-2 & 3, Under via duct Kirti Nagar Metro Station, New Delhi-110015.**
2. Type of Occupancy : **Assembly (E/H)**
3. Type of Case : **New**
4. Details of previous NOC : **Nil**
5. Fire Safety directives Letter No. : **NBC (Part-IV)**
6. Date of inspection : **16/11/2019**
7. Name of the Inspecting Officer : **A.D.O. (Jwp)**
8. Name and designation of Officer  
from the building side : **Sh. Shamdev (Manager)**
9. Year of Construction : **2018**
10. Applicant's letter No. : **37166/Addl.CP/Lic./EH (DA-V) dated 05/11/2019.**

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	2.00 mtr x 1, 1.35 mtr. x1 (Emergency Door)	2.00 Mtr. x 1, 1.50 Mtr. x 1	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	2	4	M/R
	• Types	ISI marked ABC/CO <sub>2</sub>	Provided	M/R
	• IS marking	Required	Provided	M/R

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Common with Metro Station	MR
	• Length of hose reel hose	30 Mtr.	Common with Metro Station	MR
	• Nozzle diameter	5 mm	Common with Metro Station	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	Smoke	N/A
	• Location of Main Panel	N/A	Provided	N/A
	• Location of Repeater Panel	N/A	Provided	N/A
	• Alternate source of power	N/A	Provided	N/A
	• Hooters' Location	N/A	Provided	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Ground Floor	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Common with Metro Station	MR
	• Number of hydrants per floor	N/A	Common with Metro Station	N/A
	• Hose Box	N/A	Common with Metro Station	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Common with Metro Station	MR
	➤ Head of the pump	40 MTR	Common with Metro Station	MR
	➤ Power supply	Required	Common with Metro Station	MR
	➤ Auto starting of pump	Required	Common with Metro Station	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A

15	Exit Signage	N/A	N/A	N/A
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

DO/CPD)

*[Signature]*  
18/11/19

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : A.D.O. (Jwala Puri)

Is it part of PD area of Kirti Nagar Metro Station.

*[Signature]*  
19/11/19

ADD/JWP)

Yes. It is on main road & part of Kirti Nagar Metro Stn. and property is developed by DM AC

*[Signature]*  
22/11/19

DO/CPD)

Pl. attach file of Metro Station & see requirement of PD area.

*[Signature]*  
25/11/19

ADD/JWP) Inspection report + FSC of Kirti Nagar  
+ Attach + N/A + e/s.