

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/SZ/2019/10

Dated: 07/01/20

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name & style of M/s **Lemon Drops** (A Unit of Shine Star Hospitality Pvt. Ltd) situated at T-314 & 315, Ambience Mall, Vasant Kunj, New Delhi-110070, comprised of two tiers basement, ground plus four upper floors but restaurant running at 3rd floor only have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on 11/12/2019 in the presence of Sh. Rahul Yadav and that the premises is fit for occupancy class "**Group-D Assembly**" with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/01/20 at New Delhi by

(Ajul Garg)
Director

Delhi Fire Service
Tel. 011-23414000

Copy to: -

1. The Dy. Health Officer, South Zone, South Delhi Municipal Corporation, Green Park, Aurobindo Marg, New Delhi-110016 (W.r.t. letter no. DHO/SZ/2019/D.1678 dated 27/11/2019)
2. The Authorised Signatory M/s **Lemon Drops** (A Unit of Shine Star Hospitality Pvt. Ltd) at T-314 & 315, Ambience Mall, Vasant Kunj,, New Delhi-110070

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

