

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI- 110001**

NO.F6/DFS/MS/School/2016/SZ/04

Dated: 07/01/2020

**FIRE SAFETY CERTIFICATE**

Certified that the Palam's Valley School, WZ-823, Near MCD Primary School, Palam Village, New Delhi-110045, comprised of ground plus One upper floor was Issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2016/SZ/19 dated 6.1.2017. The said school building was re-inspected by the officer concerned of this department on 27.12.2019 in presence of Sh. Vivek Solanki (Manager) and found that the Premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Cir. No. 3298-3398 dated 1.3.2011 , and that the building is fit for occupancy class B "Educational building" with effect from 07/01/20 for a period of **three years**, subject to compliance of the conditions, printed overleaf.

Issued on 07/01/20 at New Delhi by

(Rajesh Panwar)

Dy.Chief Fire Officer

Ph.011-26189168

Copy to:-

1. Director (Education), Govt. of NCT of Delhi, old Secretariat, Delhi-110054.
2. Manager, the Palam's Valley School, WZ-823, Near MCD Primary School, Palam Village, New Delhi-110045.

### CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.



2	Type of Occupancy	Educational Building "B" (Ground + First Floor)		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/School/2016/SZ/19 dated 6.1.2017		
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	27.12.2019		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Vivek Solanki (Manager)		
9	Year of construction	Before 2009		
10	Applicant's letter No.	Nil Dated 9.9.2016	(Ground plus one upper floor)	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Cir. Dated 1.3.2011/ letter dated 6.1.2017	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Direct Accessible from Road	MR
	3) Width of internal road	N/A	N/A	N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
		1.50 M & .75 M.	1.50 & 1 Mtrs.	MR
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	One	One	MR
	e. Width of corridor	1.5 Mtrs.	2.50 Mtrs.	MR
	f. Door size	1 Mtr.	1 Mtr.	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	basement	N/A	N/A	N/A
	upper floors		N/A	N/A
5	<b>Fire Extinguishers</b>			
	total numbers	Two nos. each floor Co2 OR ABC ISI	4 Nos.	MR
	Types		Co2 & ABC	MR
	ISI marking		Provided	MR



6	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/6

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Fire extinguisher near electric meter			

The fire protection system provided in the building was checked and found functional at the time of inspection.

Keeping in view deemed compliance of minimum standards on fire prevention and fire safety requirements as per DOE Circular dated 01.03.2011, renewal of fire safety certificate is recommended.

Accordingly DFA is put up for approval and signature please.

*Smy*  
S.P. Bhardwaj  
ADO Dwarka



*DCFO (S2)*

*28/12*

*DO/8W*

*30/12*

*DO/8W*

*31/12/2020*

*ADD (Dmk)*

*FT is put up for signature per*

*21/1/2020*